

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0001		3. EFFECTIVE DATE 08/25/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 09-0061	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-09-R-0061	
			X	9B. DATED (SEE ITEM 11) 08/19/09	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 11)	
CODE	FACILITY CODE				
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. ACCOUNTING AND APPROPRIATION DATA (If required)					
<b>13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>					
CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).				
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
	D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.					
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) 09-0061, Repair Damaged Fire Alarm System, Building H-1					
1. Question: Please provide the fixture schedule for the exit, emergency and exterior lights that are to be replaced.					
1. Exit lights shall be LED lights NL-61. Emergency lights shall be two head lights NL-51. Exterior lights shall be compact fluorescent NL-26 Type D 2-F 18/T4					
(CONTINUED)					
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.					
15A. NAME AND TITLE OF SIGNER (Type or print)			16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR			16B. UNITED STATES OF AMERICA		16C. DATE SIGNED
(Signature of person authorized to sign)			(Signature of Contracting Officer)		

CONTINUATION SHEET

2. Question: Spec section 2.14.14 states that an LED text sign shall be provided at all exit light locations. MCB Camp Lejeune does not currently use LED text signs for their fire alarm/mass notification systems. Are LED text signs required for the fire alarm/mass notification system, and if so, at what locations?

2. Answer: Delete requirements for LED text signs.

3. Question: Spec section 2.16.1 states to provide a graphic annunciator that indicates the building floor plan. Is a graphic annunciator required for the fire alarm system, and if so, at what location.

3. Answer: Locate graphic annunciator in main lobby.

4. Question: Spec section 2.18 is indicating that the fire alarm system is to be equipped with a fire fighter telephone system with surface mounted remote telephone stations. Will the fire alarm system be equipped with a fire fighter telephone feature, and if so, at what locations will the remote telephone stations be installed?

4. Answer: Locations for surface mounted remote telephone stations shall be designated by contracting officer.

5. Question: Spec section 2.19 states to provide weatherproof addressable manual pull stations. Will the pull stations be required to be weatherproof at all locations?

5. Answer: Provide interior pull stations are not required to be weatherproof.

6. Question: Spec section 2.24 is calling for a fiber optic transceiver as part of the mass notification interface equipment. Camp Lejeune typically uses a MadahCom TRX-401 wireless transceiver as part of their base wide mesh network for their mass notification systems. What type of mass notification interface equipment will be required and who will be providing it?

6. Answer: The government will provide the mass notification transceiver (MadahComTRX-401).