

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002	3. EFFECTIVE DATE 09/09/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0190	
6. ISSUED BY CODE	CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6		
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521				
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-08-R-0190
			X	9B. DATED (SEE ITEM 11) 08/31/09
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0190, MCAS New River NASMOD

1. Q: Will the Government provide and install the Temporary IFR Building?

1. A: Sheet E0.02 The Government will provide the Temporary IFR Building and note 6 work. Please note that there is no utility requirement for the temporary IFR Building other than the electrical feeder shown on the plan.

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

2. Sheet M3.01 Add to sequence of operation: Provide new DDC controls for AHU 2. Connect new DDC to existing DDC system. Assume existing BACnet communications. Provide VFD for AHU 2 supply fan. In cooling mode VFD shall modulate fan speed down to 1800 CFM as required to maintain space temperature. Reheat shall start at minimum flow to maintain space temperature.
3. Drawing E1.03; Add to end of Note 1; This work is not a part of the contract.
4. Drawing E1.03; add to end of Note 4; New access panels shall be anti-static. Support system is standard computer access flooring system. Color and finish of panels shall be approved by the Government.
5. Drawing MD.02; AS429 Sixth Floor Plan: Remove piping only as required to accomplish work.
6. Q: Does AS429 have an existing Fire Alarm System for the duct mounted smoke detector to interface with?
6. A: AS429 has an existing Fire Alarm System.
7. Q: Does ACC-1, 2 &3 have to be interfaced into the existing Fire Alarm System for AS427?
7. A: Interface ACC-1, 2 &3 into the existing Fire Alarm System for AS427.
8. Q: Amendment 0001 clarified that all work is part of this contract – however it is unclear as to the amount of ceiling tiles that is to be replaced. Please clarify if the ceiling in the IFR Room and the IFR Equipment Room is to be replaced.
8. A: Replace all ceiling tiles in the IFR ROOM and IFR Equipment Room.
9. All work on the temporary feeder to the temporary IFR building shall be accomplished no later than 5 OCT 2009. All work in building 427 shall be accomplished during the period 11/7/09 to 1/4/2010. All work in building 429 shall be accomplished during the period 11/21/09 to 2/13/2010.