

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0006		3. EFFECTIVE DATE 09/14/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 08-0190
6. ISSUED BY CODE		CODE	7. ADMINISTERED BY (If other than Item 6) CODE	
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521		See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)			(X)	9A. AMENDMENT OF SOLICITATION NO.
			X	N40085-08-R-0190
				9B. DATED (SEE ITEM 11) 08/31/09
				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)
CODE	FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

08-0190, MCAS New River NASMOD

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. **Question:** Since all the work associated with AS429 has been deleted per Amendment 0005, is there still a need to install the Chilled Water Buffer tank in the Mechanical Room of AS427?

1. **Answer:** Provide chilled water buffer tank as per plans.

2. **Question:** Amendment #5, note 2a states "Delete all work in building AS429." What about the work associated with building AS429 on the exterior, in particular drawing E0.02, Ground Grid and Counter Poise, and on E1.06 Lightning Protection and down cabling to Ground Grid for AS429?

Amendment #5, note 2b states "Delete all ceiling and interior lighting work in building AS427 except for that work indicated in IFR room and IFR equipment room." What about the Exit and Emergency fixtures bolded on drawing E1.02 and E2.02 in the area outside of the IFR Equipment Room and the IFR Control Room? Will these need to be replaced with new fixtures as part of the new fixtures that will be replaced in the IFR Equipment and Control Rooms? Do we disregard the requirements of notes #4 and #5?

2. **Answer:** Revise Amendment 0005, Item 2 to read:

In addition to deleting all work associated with relocation of the generator and fuel tank from the scope of this contract per Amend 0004, delete the following items also:

- a. Delete all work in building AS429 including work associated with building AS429 on the exterior, in particular drawing E0.02, Ground Grid and Counter Poise, and on E1.06 Lightning Protection and down cabling to Ground Grid for AS429.
- b. Delete all ceiling and interior lighting work in building AS427 except for that work indicated in IFR equipment room, IFR, and hallway surrounding IFR room.'