

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0007	3. EFFECTIVE DATE 09/24/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 00-4724	
6. ISSUED BY CODE	lfp	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-00-R-4724
CODE			x	9B. DATED (SEE ITEM 11) 05/19/09
FACILITY CODE				10A. MODIFICATION OF CONTRACT/ORDER NO.
				10B. DATED (SEE ITEM 11)

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

00-4724, Replace Plumbing & Mechanical System, Bldg 1212

The time and date for receipt of proposals is hereby changed to 1400 on 24 September 2009.

SEE CONTINUATION SHEETS

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. **QUESTION:** Sheet MP-3 control function points list shows points for HP-1, 2, 3, 4, 5, 6, & 7. Please clarify.

ANSWER: Delete references to HP on Control Function Points List.

2. **QUESTION:** Sheet MP-3 control function points list shows points for Existing Cond. Pump. New HX-1 does not require a Cond. pump. Please clarify.

ANSWER: Delete references to Existing Condensate Pump on Control Functions Points List.

3. **QUESTION:** Sheet MP-3 control function points list shows points for UH's. Normally these are stand alone control and not connected to the DDC controls. Please clarify.

ANSWER: Submit proposals based on specifications and drawings.

4. **QUESTION:** Sheet MP-2 please provide locations and 120vac power source for DDC panel and Jace 512.

ANSWER: Locate DDC panel on South wall, between column lines D & E. An existing panel box is on this wall. Contractor shall use twenty foot, for proposal submission purposes, to obtain 120v ac power.

5. **QUESTION:** On sheet E2A the detail shows panel 7 feeding panel 5, on sheet E2C the panel schedule for WH1 and WH2 show a 100A breaker feeding 2 panels. WH1 panel 1 & 3 and panel 2 & 4 are fed from a 3P 100A breaker, WH2 panel 5 & 7 and panel 6 & 8 are fed from a 3P 100A breaker Panel schedules for these panels do not show or indicate feed through lugs, are these required or is each panel fed with a separate 3P 100A breaker from the main panels WH1 and WH2?

ANSWER: The use of feed through lugs is what we had in mind, since we would like to reuse existing conduit. This is how the existing are connected as well.