

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0008		3. EFFECTIVE DATE 09/24/09	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 00-4724	
6. ISSUED BY CODE		lfp	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-00-R-4724
				X	9B. DATED (SEE ITEM 11) 05/19/09
					10A. MODIFICATION OF CONTRACT/ORDER NO.
					10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

00-4724, Replace Plumbing & Mechanical System, Bldg 1212

SEE CONTINUATION SHEETS

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. **QUESTION:** Is the New Fire Sprinkler System pipe mains to be installed above or below the existing 2'x4' lay in ceiling?

ANSWER: The fire sprinkler system main pipe is to be installed above the existing lay-in ceiling.

2. **QUESTION:** Amendment 1, note #5 tells us to "install drop ceiling in both restrooms approximately 10 ft high." What type of ceiling and of what grade will this be (acoustical ceiling, gyp board ceiling w/ metal stud framing, etc.)?

ANSWER: Units for Exposed-Grid System A

- a. Type: III (non-asbestos mineral fiber with painted finish).
- b. Flame Spread: Class A, 25 or less
- c. Pattern: D.
- d. Minimum NRC: 0.60 in areas when tested on mounting Type E-400 of ASTM E 795.
- e. Minimum Light Reflectance Coefficient: LR-1, 0.75 or greater.
- f. Nominal size: 24 x 24 inch.
- g. Edge detail: Reveal.
- h. Finish: Factory-applied standard finish.
- i. Minimum CAC: 40.

SUSPENSION SYSTEM

Provide standard exposed-grid standard width flange suspension system conforming to ASTM C 635 for intermediate-duty systems. Provide surfaces exposed to view of aluminum or steel with a factory-applied white color. Provide wall molding having a flange of not less than 15/16 inch. Provide standard. Suspended ceiling framing system must have the capability to support the finished ceiling, light fixtures, air diffusers, and accessories, as shown. Provide a suspension system with a maximum deflection of 1/360 of the span length. Conform seismic details to the guidance in UFC 3-310-03A and ASTM E 580.

HANGERS

Provide hangers and attachment capable of supporting a minimum 300 pound ultimate vertical load without failure of supporting material or attachment.

3. **QUESTION:** Amendment 1, note #6 tells us to "install louvers in door of restrooms." What size door louvers will be required?

ANSWER: Provide standard 20-gauge galvanized steel, 20 inch x20 inch.

4. **QUESTION:** Spec section 26 08 00 is calls for "Apparatus Inspection and Testing." Will this be required?

ANSWER: Delete specification Section 26 08 00 APPARATUS INSPECTION AND TESTING

5. **QUESTION:** Does the new Fire Sprinkler piping in the warehouse area require painting?

ANSWER: Clean, pretreat, prime, and paint new fire extinguishing sprinkler systems including valves, piping, conduit, hangers, supports, miscellaneous metalwork, and accessories. Apply coatings to clean, dry surfaces, using clean brushes. Clean the surfaces to remove dust, dirt, rust, and loose mill scale. Immediately after cleaning, provide the metal surfaces with one coat primer per schedules. Shield sprinkler heads with protective covering while painting is in progress. Upon completion of painting, remove protective covering from sprinkler heads. Remove sprinkler heads which have been painted and replace with new sprinkler heads. Provide primed surfaces with the following:

A. Piping in Unfinished Areas: Provide primed surfaces with one coat of red alkyd gloss enamel applied to a minimum dry film thickness of 1.0 mil in attic spaces, spaces above suspended ceilings, crawl spaces, pipe chases, mechanical equipment room, and spaces where walls or ceiling are not painted or not constructed of a prefinished material.

B. Piping in Finished Areas: Provide primed surfaces with two coats of paint to match adjacent surfaces, except provide valves and operating accessories with one coat of red alkyd gloss enamel applied to a minimum dry film thickness of 1.0 mil. Provide piping with 2 inch wide red enamel bands or self-adhering red plastic bands spaced at maximum of 20 foot intervals throughout the piping systems.

6. **QUESTION:** All office work deleted by amendments, however, sprinkler system design will require new sprinkler work in the offices. Are we to include this work we know will be required?

ANSWER: Include sprinkler work in the offices.

7. **Delete Item #5 from Amendment 0004 dated 11 September 2009. Priced proposals shall be submitted as a single lump sum price for all work.**