

**NAVFAC
SPECIFICATION**

**WR5017923, Replace HVAC
UMAC Office, B-87**

AMENDMENT NO. 0002

IMPORTANT

This amendment should be acknowledged when your bid is submitted. Failure to acknowledge the amendment may constitute grounds for rejection of the bid.

If your bid has been submitted prior to the receipt of this amendment, acknowledgement should be made by telegram, which should state whether the price contained in your sealed bid is to remain unchanged, is to be decreased by an amount, or is to be increased by an amount. The acknowledgement must be received prior to bid opening time.

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		1. CONTRACT ID CODE	PAGE	OF PAGES
			1	1

2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 12/1/2009	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable)
---------------------------------------	--------------------------------	----------------------------------	--------------------------------

6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-163, CURTIS ROAD PSC BOX 8006 CHERRY POINT, NC 28533	Code N40085	7. ADMINISTERED BY (If other than item 6.)	Code
--	-------------	--	------

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR BID	<input checked="" type="checkbox"/>	9A. AMENDMENT OF SOLICITATION WR5017923
		9B. DATED (SEE ITEM 11) 11/17/2009
	<input type="checkbox"/>	10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 13)
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers **is extended** **is not extended**. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. **FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.** If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

- A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
- B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
- C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
- D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor is not is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

WR5017923, REPLACE HVAC UMAC OFFICE, B-87, MARINE CORPS AIR STATION, CHERRY POINT, NORTH CAROLINA

This amendment is issued to make the following changes to the basic RFP:

RFP DUE DATE IS CHANGED TO 10 DECEMBER 2009 AT 1400 AND sent electronic to address: roicc_chpt_ktr_bids@navy.mil.

See Continuation pages.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
_____ (Signature of person authorized to sign)		_____ (Signature of Contracting Officer)	

Amendment 0002 Cont'd
WR5017923, REPLACE HVAC UMAC OFFICE BLDG 87

CONTRACT DRAWINGS:

1. NAVFAC Drawing No. 12548288, Sheet M-1; UMAC OFFICE - ARCHITECTURAL PLAN. Replace note 1 stating "REMOVE AND DEMOLISH ELEVATED 2X2 CARPET FLOOR TILE." with the following note; **"REMOVE AND DEMOLISH 2X2 CARPETED FLOOR TILES ONLY IN THE CENTER AREA OF THE MECHANICAL ROOM APPROXIMATELY 100 ft² (25-TILES). ALL CARPETED TILES UNDER WALLS SHALL REMAIN."**

2. NAVFAC Drawing No. 12548289, Sheet M-2; Replace note 4 stating "INSTALL A NEW JCI TEC #2102-3 NETWORK HEAT PUMP THERMOSTAT" with the following note; **"INSTALL A NEW JCI TEC #2102-3 NETWORK HEAT PUMP THERMOSTAT IN THE SERVER ROOM AREA."**

3. Scope of Work page 1 of 4. Section 2.a.
Replace "Work shall commence upon award of contract with all work completed within 60 days of notice to proceed." with the following note; **"Work shall commence upon award of contract with all work completed within 120 days of notice to proceed."**

4. Scope of Work page 1 of 4. Section 2.b.
Insert the following note; **"The office shall be without air-conditioning no more than 5 working days. The existing server equipment shall not be shutdown."**

5. Scope of Work page 3 of 4. Section 3.c.2.
Replace "The existing elevated carpet floor tiles shall be demolished." with the following note; **"The existing 2x2 carpeted tiles in the center area only of the mechanical room shall be demolished approximately 100 ft². Carpeted tiles under walls shall remain."**

6. Scope of Work page 4 of 4. Section 3.e.1.a
Replace "Install a JCI TEC #2102-3 network heat pump thermostat located as shown on the contract drawings, shall automatically control the associated set points with capability to be manually controlled from a control panel." with the following note; **"Install a JCI TEC #2102-3 network heat pump thermostat located in the server room, shall automatically control the associated set points with capability to be manually controlled from a control panel."**

The following are answers to RFI's not addressed above:

1. The Main Electrical Panels are located in the Main Mechanical Room which is centrally located at the back exterior of the building. See attached sketch for exact location.

2. The contractor is responsible for moving (shifting) the existing equipment to gain floor access for cleaning. The floor areas are to be cleaned as best as possible without shutting down any equipment or totally relocating equipment to a different room. The existing server computer equipment shall not be shut down for this installation.
3. The Compu-Aire unit is replaced with a standard heat pump system.
4. Scope of Work Phase 3 note 5: this refers to any simple repairs needed after final installation
5. The new tile to be installed as revised in amendment 1 is to match (similar color and type) the existing tile in the main office area. See attached sketch for exact tile replacement.
6. Contract Drawing M-2 Architectural Plan: remove note 6"x6" outside air duct w/manual damper. No outside air duct/damper required.