

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE OF PAGES 1 2
---	---------------------	----------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0004	3. EFFECTIVE DATE 09/20/11	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0139
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE rmm Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6
---	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0139
	X	9B. DATED (SEE ITEM 11) 09/14/11
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
Project 11-0139, Repair Indoor Physical Fitness Center at Bldg 401 and FC-332

The time and date for the receipt of proposals remains 1400, Wednesday, 21 September 2011.

See Continuation Page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

Amendment 0004

Project 11-0139

Page 2 of 2

- 1) Question: RFI 3 states on sheet E3 to relocate 21 of the existing 23 fans, sheet E3 is new work plan, sheet E2 is demo plan there are only 9 fans shown on sheet E2, is E3 new work or demo plan, if E3 is existing work which fixtures are existing and which are new.

Answer: See Sheet A2 Existing Conditions Ceiling Plan for locations of existing ceiling fans to be reused. See Sheets A4 and E3 Renovated Conditions Ceiling Plan for locations of reused existing fans and number and locations of new fans.

- 2) Question: Bldg FC-332, Page M-5, we are instructed to remove the existing insulation from the ductwork in the gymnasium (room 110). Then we are instructed to re-seal, re-insulate and cover with metal jacket. Typically, we do not cover ductwork with metal jacket inside a building. If it is exposed on the exterior of the building then it would be covered. If it is on the inside of the building in an enclosed space we insulate but no metal jacket. If the ductwork is exposed inside the building typically it is not insulated but if it is, normally it is not covered in metal. Brewster Middle school's ductwork in the gymnasium looks covered but it is actually double walled ductwork.

Answer: Remove the existing insulation on the duct work in the gym. Provide new insulation and metal cover on this duct work as indicated on Sheet M5.