

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT	1. CONTRACT ID CODE	PAGE 1 OF 2 PAGES
---	---------------------	-------------------

2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0003	3. EFFECTIVE DATE 09/20/11	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 11-0139
---	-------------------------------	----------------------------------	---

6. ISSUED BY CODE rmm Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521	7. ADMINISTERED BY (If other than Item 6) CODE See Item 6
---	---

8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)	(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-11-R-0139
	X	9B. DATED (SEE ITEM 11) 09/14/11
		10A. MODIFICATION OF CONTRACT/ORDER NO.
		10B. DATED (SEE ITEM 11)
CODE		FACILITY CODE

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
(a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)
Project 11-0139, Repair Indoor Physical Fitness Center at Bldg 401 and FC-332

The time and date for the receipt of proposals remains 1400, Wednesday, 21 September 2011.

See Continuation Page

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)	16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)	15C. DATE SIGNED
16B. UNITED STATES OF AMERICA (Signature of Contracting Officer)	16C. DATE SIGNED

- 1) Question: Plan sheet M-6 on the Repair FC332 project shows a points schedule with notes that mention DDC controls and a site building controller. DDC controls are not listed in the specification. Is it the intent of this project that the DDC controls be included for all scheduled pieces of HVAC equipment?

Answer: Yes, the DDC controls are to be included for all scheduled pieces of HVAC equipment. The Contractor shall tie into existing system. (Attached is DDC Spec 23 09 54)

- 2) Question: Drawings FA-4 & FA-5 notate for some work to be in Bid Option #1. There is not bid options per the bid schedule. Is this going to be a revised bid schedule or are we to price this under Priced Line Item 0002?

Answer: Work included in Drawings FA-4 & FA-5 shall be in the price for Priced Line Item 0002.

- 3) Question: There is no division 8 in our specifications for the doors and hardware.

Answer: Division 8 is included in the additional/revised specifications.

- 4) Question: On sheet A\4 there are details for the toilet accessories required for three of the restroom areas but there is not a detail for E207, the upstairs women restroom.

Answer: The upstairs Women's Toilet R207 was recently renovated prior to this project. Existing toilet accessories in R207 are to remain, except as shown in attached bulletin drawings B1 and EBD-1.

- 5) Question: FC332 sheet E3 shows several ceiling fans, these are not listed on the fixture schedule and there is not a description of these on the drawings. Please clarify.

Answer: Regarding the Ceiling Fans. Relocate 21 of the existing 23 ceiling fans to ceiling above Cycles E114 and Tread Mills E115 as indicated by detail 1 sheet E3. Provide 15 new ceiling fans in Free Weights 116 as indicated by detail 1 sheet E3. New ceiling fans shall be 54" diameter, low profile, white finish, with heavy duty quiet motor.

- 6) Question: There is not a specification for the wood trim specialty material or the wainscot material.

Answer: Wood trim and wainscot for building 401 is covered in spec section 06 20 00. That is part of the Bldg 401 Revised and Added Spec Sections.

- 7) Attached is DDC Spec section 23 09 54, which is 7 pages

- 8) Attached is "Bldg 401 Revised and Added Spec Sections" which is 213 pages.

- 9) Attached is Sheet B1, Renovated Conditions Women's Toilet R207, Bldg 401. 1 sheet.

- 10) Attached is Sheet EB1, Renovated Conditions Women's Toilet R207, Bldg 401. 1 sheet.