



W. M. JORDAN COMPANY'S BID CLARIFICATION NO. 3

*PROJECT: TOWN CREEK MIDDLE SCHOOL 100% CD BID*

*DATE: 6/21/18*

---

Please reference this Bid Clarification on the bid form.

1. **Disregard item #20 in Clarification #1. Owner does not want MC cable due to maintenance concerns. Use EMT.**
2. Question: Question: Would it be possible to get the CPT raw data from the geotechnical report for subcontractors bidding the earthquake drains?

Answer: CPT raw data is now available. Visit WMJ plan room to access.