

LOCATIONS AND TYPES OF PORTABLE FIRE EXTINGUISHERS

<u>Location</u>	<u>Circle Type Extinguisher</u>	<u>Number</u>	<u>Last Annual Check</u>	<u>Remarks</u>
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____
_____	A B C D H	_____	_____	_____

Class A Fire Extinguishers. Use on ordinary combustibles or fibrous material, such as wood, paper, cloth, rubber and some plastics. Travel distance for employees to any extinguisher is 75 feet (22.9m) or less.

Class B Fire Extinguishers. Use on flammable or combustible liquids such as gasoline, kerosene, paint, paint thinners and propane. Travel distance from the Class B hazard area to any extinguisher is 50 feet (15.2m) or less.

Class C Fire Extinguishers. Use on energized electrical equipment, such as appliances, switches, panel boxes and power tools. Travel distance from the Class C hazard area to any extinguishing agent is 50 feet (15.2m) or less.

Class D Fire Extinguishers. Use on combustible metals, such as magnesium, titanium, potassium and sodium. Travel distance from the combustible metal working area to any extinguishing agent is 75 feet (22.9m) or less.