

FIRE ALARM RISER

NTS

NOTE: INTERFACE NEW FIRE CURTAIN W/PANEL TO CLOSE ON ALARM

NOTES:


1. CONNECT NEW DEVICES & APPLIANCES TO THE EXISTING SYSTEM. NEW DEVICES & APPLIANCES SHALL BE UL LISTED FOR USE WITH THE EXISTING SYSTEM.
2. ALL NEW FIRE ALARM WORK SHALL COMPLY W/ NFPA 72 AND ALL REQUIREMENTS OF THE LOCAL AUTHORITY HAVING JURISDICTION.
3. CABLES SHALL BE AS RECOMMENDED BY SYSTEM MANUFACTURER.
4. TEST AND CERTIFY SYSTEM.
5. UPDATE OWNER'S DOCUMENTATION.
6. FIRE ALARM CONTRACTOR SHALL SUBMIT SHOP DRAWINGS AND ALL REQUIRED DOCUMENTATION AND CALCULATIONS TO THE AHJ FOR PERMIT APPLICATION AND APPROVAL.

REFERENCE NOTES:

1. REPLACE 4 EXISTING DIMMERS W/NEW 0-10V DIMMING IN DIMMING CABINET
2. CONNECT TO EXISTING LIGHTING BRANCH CIRCUIT. RE-USE EXISTING SWITCHES.
3. CONNECT TO NEAREST RECEPTACLE CIRCUIT.
4. CONNECT LED LIGHT STRIP UNDER WELCOME DESK.
5. PROVIDE RECEPTACLE IN WELCOME DESK TOP, CONCEALED WITH POP-UP ASSEMBLY.
6. REMOVE LIGHT FIXTURE AND RE-INSTALL. COORDINATE WITH G.C.

SANCTUARY BUILDING (ALT BID) FIRST FLOOR PLAN A – ELECTRICAL

SCALE: 1/8"=1'-0"



hostellerarchitecture

■ ARCHITECTURE ■ PLANNING


3967 MARKET STREET
WILMINGTON, NC 28403

PHONE: 910.612.1119


www.hostellerarchitecture.com

CONSULTANTS

10755



McDOWELL CONSULTING
ENGINEERS, INC.
P.O. BOX 367
HAMPSTEAD, NC 28443
TEL (910) 270-3747 FAX 270-3779
NC LICENSE NO. C-2546



RENOVATIONS TO

GRACE BAPTIST CHURCH

WILMINGTON
NORTH CAROLINA

CONSTRUCTION DOCUMENTS : 2.8.19

REVISIONS

MARK	DATE	DESCRIPTION
2	4.9.19	BIDDER CLARIFICATIONS
3		
4		
5		

DRAWN BY: RSG PROJ. MGR: GLM

SHEET CONTENT

SANCTUARY BUILDING (ALT BID)
FIRST FLOOR PLAN - A
ELECTRICAL - ELECTRICAL

JOB NO.
18013

SHEET
E205