

RECORD DRAWING

This drawing is revised to show construction conditions in place based on mark-up drawings provided by the contractor utilizing methods of reasonable practice and care. Field verification by the Engineer was not provided.

Dated:-----
By:-----

KEYED NOTES:

1. M.C. TO TIE-IN TO EXISTING HWS AND HWR PIPING AND INSTALL NEW BRANCH PIPING TO HOT WATER COIL OF NEW FAN BOX 21C.
2. M.C. TO INSTALL NEW FAN BOX 21C AND RELATED DUCT WORK AS SHOWN ON PLAN.
3. M.C. TO RE-INSTALL AND RE-BALANCE EXISTING LINEAR 5/A DIFFUSERS IN LOCATION SHOWN ON PLAN.
4. M.C. TO ADD FIRE DAMPER AND ACCESS DOOR TO EXISTING DUCTWORK.
5. M.C. TO ADD FIRE DAMPER AND ACCESS DOOR TO NEW DUCTWORK.
6. M.C. SHALL RELOCATE EMERGENCY SAFETY SHOWER AS SHOWN. REMOVE WATER SUPPLY PIPING ABOVE CEILING BACK TO RELOCATED SHOWER SIDE OF NEW RATED WALL. RECONNECT TO RELOCATED SHOWER.
7. M.C. SHALL RELOCATE SENSOR AS SHOWN.

