


Job No.:	10032
Drawn:	MDM
Designed:	MDM
Checked:	WAC

Drawing No:	E1.1
-------------	-------------

Revision:	1
-----------	----------


$$1/4'' = 1'-0''$$

16. BACKWASH PENETRATING FLOORS, CEILING OR WALLS SHALL BE PROPERLY SEALED IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
17. BACKWASH PENETRATING FLOORS, CEILING OR WALL ASSEMBLIES SHALL BE PROPERLY SEALED SMOKE-TIGHT.
18. ALL JOINTS AND SEAMS OF INSULATION SHALL BE PROPERLY SEALED TO PREVENT AIR LEAKAGE. USED PRESTRESSING MATERIALS AND MANUFACTURER APPROVED INSULATION TECHNIQUES COMPLYING WITH APPLICABLE CODES. SEE ARCHITECTURAL DRAWINGS FOR IDENTIFICATION OF Joints AND CEILINGS.
19. PATCHING OF INTERPENOETRATED SURFACES SHALL RENDER THE AREA OF THE PATCHING COMPLETELY WEATHERPROOF.
20. ALL MOTORS AND OTHER VIBRATING EQUIPMENT SHALL BE CONNECTED TO THE CONDUIT SYSTEM BY MEANS OF A RIGIDLY SUPPORTED, NON-FLEXIBLE CONDUIT. THE CONDUIT SHALL BE INSTALLED INSIDE THE FLEXIBLE CONDUIT AND TERMINATE AT THE LOAD END WITH AN APPROVED GROUNDING CLAMP OR LUG.

37. EXISTING CIRCUITING WHERE SHOWN IS FOR CONVENIENCE PURPOSES ONLY. VERIFICATION OF EXISTING WIRING DESTINATION, TERMINATION AND ADDITIONS OF NEW LOADS IS THE RESPONSIBILITY OF THE CONTRACTOR.

38. MAINTAIN CONTINUITY OF ALL EXISTING CIRCUITS TO REMAIN OR PORTIONS THEREOF AFFECTED BY THIS WORK.

39. TRACE OUT EXISTING WIRING THAT IS TO BE RELOCATED, OR REMOVED AND PERFORM THE RELOCATION OR REMOVAL WORK AS REQUIRED FOR A WORK THAT IS OBSERVING AND SAFE SYSTEM

[illegible]

Dated: 10-10-15
By: [Signature]