



GENERAL NOTES	
A. UNLESS INDICATED OTHERWISE, ALL COUNTERTOPS:	
• 3'-0" AFF OR 3'-0" TO TOP OF RIM AT DROP-IN SINKS AND LAVATORIES WHERE OCCURS	
• 2'-6" DEEP	
• BLACK EPOXY RESIN, 1" THICK	
• BACKSPASHES: 4" HIGH AT PERIMETER AND AS NOTED	
B. UNLESS INDICATED OTHERWISE, ALL BASE CABINET(S):	
• 22" DEEP NOMINAL	
• TOE KICKS: 4" HIGH AND 3" DEEP	
C. UNLESS INDICATED OTHERWISE, ALL WALL CABINET(S):	
• 1'-1" DEEP NOMINAL	
• 2'-6" HIGH	
• TOP AT 7'-0" AFF	
D. PROVIDE SOLID BLOCKING FOR ALL WALL MOUNTED ITEMS	
E. INSTALL RUBBER BASE ON THE BASE OF ALL CASEWORK	
F. BUILT-IN EQUIPMENT: SIZE OPENING (HEIGHT, WIDTH AND DEPTH) AND ROUGH-IN REQUIREMENTS AS REQUIRED BASED ON APPROVED MANUFACTURER SUBMITTED.	
G. ALL SHELVES: ADJUSTABLE UNLESS INDICATED OTHERWISE	
H. PROVIDE FINISH END PANELS AT ALL EXPOSED CASEWORK ENDS.	
I. LOCKS: AS INDICATED.	
J. MOUNT ALL WHITE BOARDS AND CHALK BOARDS AT 4'-0" AFF, UNO	
K. TALL STORAGE CABINETS SHALL BE SECURED TO THE WALL TO PREVENT TIPPING	
L. ALL LAB EQUIPMENT IS OFCI	
M. CM SHALL COORDINATE WITH OWNER FOR LOCATIONS OF OFCI PROJECTORS	
N. REFER TO SINK SCHEDULE FOR IDENTIFICATION OF FIXTURES AND ACCESSORIES	

SCIENCE CASEWORK KEYNOTES	
REPRESENTED BY [n]	
APPLIES TO DRAWINGS A7.4.1 - A7.4.n	
1	RUBBER BASE
2	KNEE SPACE
3	BACK PANEL
4	END PANEL
5	SLIDING GLASS DOORS
6	FILLER PANEL
7	LOCK
8	FUME HOOD SHROUD, EXTEND TO CEILING
9	UMBILICAL; SEE DETAIL n/A7.4.X
10	WALL SHELVING; SEE DETAIL n/A7.4.X
11	DRYING RACK; SEE DETAIL n/A7.4.X
12	ADJUSTABLE REAGENT SHELVING
13	REAGENT SHELVING; SEE DETAIL n/A7.4.X
14	ELECTRICAL RACEWAY

