



REPRESENTED BY [ ]

1. FIELD VERIFY OUTLET LOCATIONS FOR THIS SPACE. IF EXISTING OUTLET IS IN CLOSE PROXIMITY TO THE NEW DEVICE INDICATED, DO NOT PROVIDE NEW DEVICE.
2. CIRCUIT NEW POWER DEVICES IN THIS SPACE TO LOCAL 120V RECEPTACLE CIRCUIT.
3. EXISTING BREAKERS FEED BY DEMOLITION MAY BE USE 0.0 CIRCUITS INDICATED. ADJUST PANEL SCHEDULE ON AND RECORD CHANGES ON AS-BUILT DOCUMENTS.
4. REMOVE THE EPO BUTTON IN THIS SPACE. PROVIDE BLACK OVER THE EXISTING BOX AND DISCONNECT THE SHUNT TRIP MAIN IN THIS PANEL.
5. PROVIDE OUTLET FOR AREA PHONE TO MATCH THE EXISTING CURRENTLY LOCATED IN THE STAIRWELLS. PROVIDE TWO CAT 6 DATA CABLE TO NEAREST DATA CLOSET. OWNER SHALL PROVIDE THE EQUIPMENT.
6. PROVIDE 600V, 80A, 3P, DISCONNECT FPND, COORDINATE MOTOR LOCATION WITH ELEVATOR PROVIDER AND PROVIDE FEEDER SIZE INDICATED TO ELEVATOR MOTOR.
7. LOCATE A 250V/1P/20A DISC FUSED AT 20A FOR ELEVATOR CAB LIGHTING
8. LOCATE PHONE OUTLET ADJACENT TO ELEVATOR CONTROLLER.
9. COORDINATE THE LOCATION OF THE NON-GFI OUTLET WITH THE LOCATION OF THE SUMP PUMP CONTROLLER. PROVIDE 1"CF FROM CONTROLLER TO SUMP PUMP.
10. CONNECT LIGHT TO LINE SIDE OF THE GFI OUTLET. PROVIDE WATERPROOF LIGHT SWITCH NEAR THE TOP OF THE PIP LADDER.
11. COORDINATE THE LOCATION OF ALL ELECTRICAL EQUIPMENT WITH ELEVATOR EQUIPMENT IN THE ROOM FLOOR TO ROUGHIN.
12. RECONNECT DESKTOP POWER TO EXISTING POWER SOURCE IN THE FLOOR. FIELD VERIFY LOCATION.
13. REMOVE THE OUTLET IN THE BOX MOUNTED IN THE VERTICAL FACE OF THE RISER AND ITS ASSOCIATED WIRING. PROVIDE BLACK COVER PLATE FOR EMPTY BOX. FIELD VERIFY QUANTITY.
14. FIELD VERIFY LOCATION OF FLOOR BOX WITH OWNER PRIOR TO ROUGHIN. PROVIDE BREAKER IN AVAILABLE SPACE OF PANEL INDICATED.

DWG E2.3.2

DWG E2.3.3

## SECOND FLOOR PLAN - PART B - ELECTRICAL

$$1/8" = 1'-0"$$