

DIV 23 ELECTRICAL CONNECTION SCHEDULE E2.2.4

TAG	VOLTAGE	# POLES	LOAD	PANEL	CCT#	WIRE	DISCONNECTING MEANS	REMARKS
AHU-2.1 VFD	480 V	3	11.2 KVA	10E	13.5	3#12+2#10.34"	DIW 23 PROVIDED VFD	
AHU-2.3 VFD	480 V	3	11.2 KVA	10E	2.6	3#12+2#10.34"	DIW 23 PROVIDED VFD	
AHU-2.3 VFD	480 V	3	11.2 KVA	10E	79.11	3#12+2#10.34"	DIW 23 PROVIDED VFD	
AHU-2.4 VFD	480 V	3	11.2 KVA	10E	8.10, 12	3#12+2#10.34"	DIW 23 PROVIDED VFD	
BC-2	120 V	1	0.3 KVA	1EMPB	5	2#12+10.34"	DIRECT CONNECTION	
EV2-1	120 V	1	0.1 KVA	1LPT	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1	120 V	1	0.1 KVA	1LPT	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-3.1	120 V	1	0.1 KVA	1LPW	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-4.1	120 V	1	0.1 KVA	PAI	3	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-5.1	120 V	1	0.1 KVA	PAI	3	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-7.1	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-8.1	120 V	1	0.1 KVA	1LPP	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-10.1	120 V	1	0.1 KVA	B	5	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-12.1	120 V	1	0.1 KVA	B	5	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-14.1	120 V	1	0.1 KVA	PAI	2	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-16.1	120 V	1	0.1 KVA	PAI	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-18.1	120 V	1	0.1 KVA	1LPS	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.1	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.2	120 V	1	0.1 KVA	1LPS	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.3	120 V	1	0.1 KVA	1LPS	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.4	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.5	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.6	120 V	1	0.1 KVA	1LPW	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.7	120 V	1	0.1 KVA	1LPW	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.8	120 V	1	0.1 KVA	1LPW	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.9	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.10	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.11	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.12	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.13	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.14	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.15	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.16	120 V	1	0.1 KVA	1LPM	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.17	120 V	1	0.1 KVA	PAI	2	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.18	120 V	1	0.1 KVA	PAI	2	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.19	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.20	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.82	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.83	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.84	120 V	1	0.1 KVA	1LPJ	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.19	120 V	1	0.1 KVA	1LPJ	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.92	120 V	1	0.1 KVA	1LP2	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SPAC
EV2-1.20	120 V	1	0.1 KVA	1LPB8	1	2#12+10.34"	MOTOR RATED SNAP SWITCH	RECONNECT TO EXISTING CCT IN SP

[illegible]