

## SECTION 260500 - GENERAL ELECTRICAL

## PART 1 - GENERAL

## 1.1 SCOPE OF WORK

- A. The Instructions to Bidders, General Conditions of the Contract, Supplementary General Conditions and Division 1 bound herewith are a component part of this Division of the specifications and shall apply to this Division with equal force and shall be consulted in detail for instructions pertaining to the work.
- B. Furnish all labor, materials and equipment and incidentals required to make ready for use complete electrical systems as shown on the Drawings and specified herein.
- C. It is the intent of these Specifications that the electrical systems shall be suitable in every way for the service required. All material and all work which may be reasonably implied as being incidental to the work of this Division shall be furnished at no extra cost.
- D. The work shall include, but not be limited to, furnishing, coordinating, and installing the following:
  - 1. Electrical distribution system for power, and miscellaneous power as shown on the contract drawings.
  - 2. Grounding.
  - 3. Other special requirements and/or systems where shown.
- E. Each bidder (or Representative) shall, before preparing a proposal, visit all areas of the existing site. If the work includes demolition, restoration, renovation and/or addition; then existing buildings and structures should be carefully inspected. The submission of the proposal by this Bidder shall be considered evidence that the Bidder (or Representative) has visited the site and noted the locations and conditions under which the work will be performed and that the Bidder takes full responsibility for a complete knowledge of all factors governing the work.
- F. All power interruptions to existing equipment shall be at the Owner's convenience with 24 hours (minimum) notice. Each interruption shall have prior approval.
- G. The work shall include complete testing of all equipment and wiring at the completion of work and making any minor correction changes or adjustments necessary for all the proper functioning of the system and equipment. All work shall be of the highest quality; substandard work will be rejected.
- H. Field verify all existing underground electrical and mechanical piping.

## 1.2 SUBMITTALS

- A. Shop drawings shall be submitted for all equipment, apparatus, and other items as required by the Architect/Engineer. Submit under provisions of relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.

- B. Submittals are required for all materials shown in the individual specifications sections.
- C. Submittals are required for materials used for penetrations of rated assemblies and for seismic restraints.
- D. All shop drawings and submittals shall be submitted at the same time. Partial shop drawing and submittals will be rejected and not processed. Materials, equipment and long lead items that require special handling, if identified and requested by the contractor, will be processed separately.
- E. Proposed equipment and/or materials substitutions shall be clearly indicated in shop drawings. All deviations from the specified quality, functionality, appearance or performance of the proposed equipment and/or materials shall be clearly summarized in the preface of each submittal.
- F. The project shall be bid based on the equipment listed in these specifications and on the drawings. After award of the Electrical Contract the Contractor may wish to substitute equipment other than that specified, subject to approval. The Electrical Contractor shall bear the "burden of proof" for demonstrating substitute equipment equivalency and suitability.
- G. The Electrical Contractor shall be required to replace installed "equivalent" equipment if the operation of this equipment does not meet the full design intent of the specified system.
- H. Physical size of equipment used in the design layout are those of reputable equipment manufacturers. The Contractor is responsible for providing equipment which will fit the space provided. If the Contractor elects to use other manufacturer's equipment, any resulting conflicts with space clearance or codes shall be the responsibility of the Contractor to correct at the Contractor's expense.
- I. The Contractor assumes all responsibility for providing code clearances. Submit a scale drawing of each electrical equipment room showing exact size and location of all proposed electrical equipment with code clearances and working space clearly indicated.

### 1.3 COORDINATION OF WORK

- A. It is understood and agreed that the Contractor is, by careful examination, satisfied as to the nature and location of the work, the conformation of the ground, the character, quality and quantity of the materials to be encountered, the general and local conditions and all other matters which can and may affect the work under this contract. The Contractor shall be held responsible for visiting the site and thoroughly familiarizing himself with the existing conditions and also any contractual requirements as may be set forth in the other Divisions of these Specifications. No extras will be considered because of additional work necessitated by obvious job conditions that are not indicated on the drawings.
- B. The Contractor shall compare the electrical drawings and specifications with the drawings and specifications for other trades, and shall report any discrepancies between them to the Architect/Engineer and obtain written instructions for changes necessary in the electrical work. The electrical work shall be installed in cooperation with other trades installing interrelated work. Before installation, the Contractor shall make proper provisions to avoid interferences in

a manner approved by the Architect/Engineer. All changes required in the work of the Contractor caused by neglect to do so shall be made at the expense of the Contractor.

- C. Location of electrical raceways, switches, panels, equipment, fixtures, etc., shall be adjusted to accommodate the work to interferences anticipated and encountered. The Contractor shall determine the exact route and location of each electrical raceway prior to make up and assembly.
1. Right of Way: Lines which pitch shall have the right of way over those which do not pitch. For example, steam, condensate and plumbing drains shall normally have right of way. Lines whose elevations cannot be changed shall have the right of way over lines whose elevations can be changed.
  2. Offsets and changes in direction of electrical raceways shall be made as required to maintain proper headroom and to clear pitched lines whether or not indicated on the drawings. The Contractor shall furnish and install elbows, pull boxes, etc., as required to affect these offsets, transitions, and changes in directions. Conflicts between electrical raceways, fixtures, etc., and ductwork or piping which cannot be resolved otherwise, will be resolved by the Architect/Engineer.
- D. Installation and Arrangements: The Contractor shall install all electrical work to permit removal (without damage to other parts) of any equipment requiring periodic replacement or maintenance. The Contractor shall arrange electrical raceways and equipment to permit ready access to valves, cocks, traps, starters, motors, control components, etc., and to clear the opening of swinging and overhead doors and of access panels.

#### 1.4 EQUIPMENT AND MATERIALS (GENERAL)

- A. In compliance with North Carolina General Statute 133.3, the Architect/Engineer has, wherever possible, specified the required performance and design characteristics of all materials utilized in this construction. In some cases it is impossible to specify the required performance and design characteristics and when this occurs the Architect/Engineer has specified three or more examples of equal design or equivalent design, establishing an acceptable range for items of equal or equivalent design. Cited examples are used only to denote the quality standard of product desired and do not restrict bidders to a specific brand, make, manufacturer or specific name and are used only to set forth and convey to bidders the general style, type, character and quality of product desired. Equivalent products will be acceptable.
- B. Substitution of materials, items, or equipment of equal or equivalent design shall be submitted to the Architect/Engineer for approval or disapproval. Equal or equivalent shall be interpreted to mean an item of material or equipment, similar to that named and which is suitable for the same use and capable of performing the same functions as that named, the Architect/Engineer being the judge of equality.
- C. The materials used in all systems shall be new, unused and as hereinafter specified and shall bear the manufacturer's name, trade name and third party testing agency label (Third party agencies shall be amongst those accredited by the North Carolina Building Code Council to Label Electrical and Mechanical Equipment) in every case where a standard has been established for the particular material. Equipment furnished under this specification shall be essentially the standard product of manufacturers regularly engaged in the production of the required type of equipment, and shall be the manufacturer's latest approved design. All materials where not specified shall be of the very best of their respective kinds. Samples of

materials or manufacturer's specifications shall be submitted for approval as required by the Architect/Engineer.

- D. Protection: Electrical equipment shall at all times during construction be adequately protected against damage. Equipment shall be tightly covered and protected against dirt, water and chemical or mechanical injury and theft. Electrical equipment shall not be stored out-of-doors. Electrical equipment shall be stored in dry, permanent shelters. If an apparatus has been damaged, such damage shall be repaired at no additional cost. If any apparatus has been subject to possible injury by water, it shall be replaced at no additional cost to the Owner. At the completion of the work, fixtures, equipment, and materials shall be cleaned and polished thoroughly and turned over to the Owner in a condition satisfactory to the Architect/Engineer. Damage or defects, developing before acceptance of the work shall be made good at the Contractor's expense.
- E. Any damage to factory applied paint finish shall be repaired using touch-up paint furnished by the equipment manufacturer. The entire damaged panel or section shall be repainted per the field painting specifications in Division 9, at no additional cost to the Owner.
- F. Where materials such as wiring devices and plates, fire alarm equipment, paging system components, etc. are specified to match existing, provide materials to match existing equipment in finish, color, capacity, ratings, operating characteristics, performance, etc.
- G. Delivery and Storage: Equipment and materials shall be delivered to the site and stored in original containers, suitably sheltered from the elements, but readily accessible for inspection by the Architect/Engineer until installed.
- H. Equipment and materials of the same general type shall be of the same make throughout the work to provide uniform appearance, operation and maintenance.
- I. Manufacturer's directions shall be followed completely in the delivery, storage, protection, and installation of all equipment and materials. The Contractor shall promptly notify the Architect/Engineer, in writing, of any conflicts between any requirements of the Contract Documents and the manufacturer's directions and shall obtain the Architect/Engineer's written instructions before proceeding with the work. Should the Contractor perform any work that does not comply with the manufacturer's direction or such written instructions from the Architect/Engineer, the Contractor shall bear all costs arising in correcting the deficiencies.

#### 1.5 OPERATION AND MAINTENANCE MANUALS

- A. Submit under relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. The Contractor shall provide two compilations of catalog data, bound in suitable loose leaf binders, for each manufactured item of equipment used in the electrical work. These shall be presented to the Architect/Engineer for transmittal to the Owner before the final inspection is made. Data shall include printed installation, operation and maintenance instructions for each item, indexed by product with heavy sheet dividers and tabs. All warranties shall be included with each item. Each manufacturer's name, address and telephone number shall be clearly indicated.

- C. Shop drawings with Architect/Engineer's "as noted" markings are not acceptable for the above. "Approved" shop drawings are acceptable if adequate information is contained therein. Generally, shop drawings alone are not adequate.

#### 1.6 PAINTING

- A. All painting will be performed by the General Contractor for the project, unless specifically indicated otherwise.
- B. The Electrical Contractor shall clean all exposed electrical work for painting. Should the Electrical Contractor delay in installing exposed conduit and outlets until the General Contractor has begun painting, the Electrical Contractor shall be required to paint all exposed electrical work at the Electrical Contractor's own expense. Such painting will be accomplished in accordance with the detailed specifications for the Project.
- C. Conductors exposed in boxes and cabinets shall be protected against painting. Devices, cover plates, trims, etc., for panelboards and cabinets shall not be installed until painting has been completed.
- D. The Electrical Contractor shall be responsible for touch up painting that may be required for electrical material or apparatus furnished with factory applied finish.

#### 1.7 LOCATIONS AND MEASUREMENTS

Outlets and appliances are shown and located on the drawings as accurately as possible. All measurements shall be verified on the project and in all cases the work shall suit the surrounding trim, finishes and/or construction. The locations of outlets for special appliances shall be installed so that when extended, they are flush with the finished wall or ceiling and permit the proper installation of fixtures and/or devices. Heights of all outlets shown on the drawings are approximate only. Slight relocations of outlets, devices and equipment shall be made by the Contractor as required or as directed by the Architect/Engineer at no additional cost to the Owner.

#### 1.8 QUALITY OF WORK

All work shall be executed as required by this specification and the accompanying drawings and shall be done by skilled mechanics, and shall present a neat, trim, and mechanical appearance when completed. All work shall be performed as required by the progress of the job.

#### 1.9 SUPERVISION

- A. The Contractor shall personally, or through an authorized and competent representative, constantly supervise the work from the beginning to completion and final acceptance. So far as possible, the Contractor shall keep the same foreman and mechanics throughout the project duration.
- B. During the progress of the work it shall be subject to inspection by representatives of the Architect/Engineer, the Owner, and local inspection authorities, at which time the Contractor shall furnish such required information and data on the project as requested.

- C. The Electrical Contractor shall coordinate the electrical work with other Contractors and cooperate in the preparation and maintenance of a master schedule for the completion of the project.

#### 1.10 CLOSING IN WORK

Work shall not be covered up or enclosed until it has been inspected, tested and approved by the authorities having jurisdiction over this work. Should any of the work be enclosed or covered up before such inspection and test, the Contractor shall uncover the work at the Contractor's expense; after it has been inspected, tested and approved, the Contractor shall restore the work to its original condition. The electrical contractor is responsible for notifying the Office of the State Electrical Inspector at the State Construction Office to schedule required inspections including rough-in, above ceiling and final inspections.

#### 1.11 REFERENCE STANDARDS

- A. All electrical equipment, materials, and installation shall be in accordance with the latest edition of the following codes and standards:
1. American Association of Edison Illuminating Companies (AEIC)
  2. American National Standards Institute (ANSI)
  3. American Society for Testing and Materials (ASTM)
  4. Building Officials Code Administrators (BOCA)
  5. Energy Code 90.1 (ASHRAE/IES)
  6. Institute of Electrical and Electronic Engineers (IEEE)
  7. Insulated Cable Engineers Association (ICEA)
  8. International Code Council (ICC)
  9. International Conference of Building Officials (ICBO)
  10. National Electrical Code (NEC) 2017 edition
  11. National Electrical Contractor's Association (NECA)
  12. National Electrical Installation Standards (NEIS)
  13. National Electrical Manufacturer's Association (NEMA)
  14. National Electrical Safety Code (NESC)
  15. National Fire Protection Association (NFPA)
  16. North Carolina State Building Code (NCSBC)
  17. North Carolina Construction Manual with GS as listed (NCCM)
  18. Occupational Safety and Health Act (OSHA)
  19. Requirements of the Americans with Disabilities Act (ADA), latest edition.
  20. Underwriters Laboratories Inc (UL)
  21. Southern Building Code Congress International (SBCCI)
  22. Toxicity Characteristics Leaching Procedure (TCLP)
  23. North Carolina Energy Conservation Code
- B. All electrical equipment and material shall be listed by an approved third party testing agency approved by the NCBCC (North Carolina Building Code Council) and shall bear the appropriate testing agency's listing mark or classification marking. Equipment, materials, etc. utilized not bearing a third party testing agency certification shall be field or factory third party testing agency certified prior to equipment acceptance and use.

- C. Where reference is made to one of the above standards, the revision in effect at the time of the bid opening shall apply.

#### 1.12 ENCLOSURE TYPES

Unless otherwise specified herein or shown on the Drawings, electrical enclosures shall have the following ratings:

1. NEMA 1 for dry, indoor locations.
2. NEMA 3R for outdoor locations, rooms below grade (including basements and buried vaults), "DAMP" and "WET" locations.
3. NEMA 4X for locations subject to corrosion when specifically noted.

#### 1.13 CORROSION PROTECTION

All equipment and hardware subject to exposure to the elements and/or not installed in a conditioned space shall be fabricated of non-metallic materials, hot dip galvanized after fabrication or stainless steel. The requirements of preceding section entitled "Delivery and Storage" shall be strictly followed. Touch up any scratched metallic surfaces immediately to prevent corrosion. Apply cold galvanizing compound to all galvanized surfaces damaged during installation, i.e., cutting, etc. Ferrous, rusted or corroded materials shall be replaced before final acceptance of the work.

#### 1.14 CODES, INSPECTION AND FEES

- A. All equipment, materials and installation shall be in accordance with the requirements of the local authority having jurisdiction.
- B. The Electrical Contractor shall obtain all necessary permits and pay all fees required for permits and inspections of electrical work.
- C. The Electrical Contractor shall contact Code Officials to schedule any and all required inspections.

#### 1.15 TESTS AND SETTINGS

- A. Test all systems furnished under Division 26 and repair or replace all defective work. Make all necessary adjustments to the systems and instruct the Owner's personnel in the proper operation of the systems.
- B. Make the following minimum tests and checks prior to energizing electrical equipment:
  1. Mechanical inspection, testing and settings of all circuit breakers, disconnect switches, motor starters, control equipment, etc., for proper operation.
  2. Check all wire and cable terminations. Verify to the Architect/Engineer that connections meet the equipment torque requirements.
  3. Check rotation of motors, obtain permission from other contractors to start motor, and proceed to check for proper rotation. If the motor rotates in the wrong direction, correct it. Take all necessary precautions not to damage any equipment.
  4. Provide all instruments and equipment for the tests specified herein.

- C. All testing shall be scheduled and coordinated by the Contractor. Notify the Owner at least two (2) weeks in advance of conducting tests. The Contractor shall have qualified personnel present during all testing.
- D. All tests shall be completely documented with the time of day, date, temperature, and all other pertinent test information. All required documentation of readings indicated shall be submitted to the Architect/Engineer prior to, and as one of the prerequisites for, final acceptance of the project.
- E. Electrical Distribution System Tests: All current carrying phase conductors and neutrals shall be tested as installed, and before load connections are made, for insulation resistance and accidental grounds. This shall be done with a 500 volt megger. The following procedures shall be as follows:
  - 1. Minimum readings shall be one million (1,000,000) ohms or more for #6 AWG wire and smaller; 250,000 ohms or more for #4 AWG wire or larger. Measurement to be taken between conductors and between conductor and the grounded metal raceway.
  - 2. After all fixtures, devices and equipment are installed and all connections completed to each panel, the Contractor shall disconnect the neutral feeder conductor from the neutral bar and take a megger reading between the neutral bar and grounded enclosure. If this reading is less than 250,000 ohms, the Contractor shall disconnect the branch circuit neutral wires from this neutral bar. The Contractor shall then test each one separately to the panel until the low reading ones are found. The Contractor shall correct troubles, reconnect and retest until at least 250,000 ohms from the neutral bar to the grounded panel can be achieved with only the neutral feeder disconnected.
  - 3. The Contractor shall send a letter to the Architect/Engineer, and to the North Carolina State Construction Office certifying that the above has been done and tabulating the megger readings for each panel. This shall be done at least four (4) days prior to final inspection.
  - 4. At inspection, the Contractor shall furnish a megger and show Architect/Engineer's representative that the panels comply with the above requirements. The Contractor shall also furnish a clamp type ammeter and a voltmeter and take current and voltage readings as directed by the representatives.
  - 5. At inspection, the Contractor shall furnish ladders, required tools, and mechanics to open fixtures, boxes, panels, or any other equipment to enable the Architect/Engineer's representatives to see into any parts of the installation that may be requested.
- F. Electrical Grounding System Tests: Provide documentation showing values of earth ground impedance for the system ground. See Specifications Section 260526 for testing requirements.

#### 1.16 SLEEVES AND FORMS FOR OPENINGS

- A. Anchor bolts, sleeves, inserts, supports, etc., that may be required for electrical work shall be furnished, located and installed by the Electrical Contractor. The Electrical Contractor shall give sufficient information (marked and located) to the General Contractor in time for proper placement in the construction schedule. Should the Electrical Contractor delay or fail to provide sufficient information in time, then the Electrical Contractor shall cut and patch construction as necessary and required to install electrical work. Such cutting and patching will be done by the General Contractor but paid for by the Electrical Contractor.

- B. Provide and place all sleeves for conduits penetrating floors, walls, partitions, etc. Locate all necessary slots for electrical work and form before concrete is poured.
- C. Where exact locations are required by equipment for stubbing-up and terminating conduit concealed in floor slabs, request shop drawings, equipment location drawings, foundation drawings, and any other data required to locate the concealed conduit before the floor slab is poured.
- D. Where such data is not available in time to avoid delay in scheduled floor slab pours, the Architect/Engineer may elect to allow the installations of such conduits to be exposed. No additional compensation for such change will be allowed and written approval must be obtained from the Architect/Engineer.
- E. Seal all openings, sleeves, penetration, and slots as specified and as shown on the Contract Drawings.

#### 1.17 CUTTING AND PATCHING

- A. For the purposes of the Electrical Contract, “cutting and patching” shall be defined as that work required to introduce new electrical work into existing construction. Work required to install or fit electrical boxes, conduit, enclosures, equipment, etc. into new construction is not “cutting and patching”.
- B. The Electrical Contractor shall perform all cutting and patching necessary to install all equipment as required under his contract and shall re-establish all finishes to their original condition where cutting and patching occur.
- C. All cutting and patching shall be done in a thoroughly workmanlike manner.
- D. Core drill holes in existing concrete floors and walls as required.
- E. Install work at such time as to require the minimum amount of cutting and patching.
- F. Do not cut joists, beams, girders, columns or any other structural members without first obtaining written permission from the Architect/Engineer.
- G. Cut opening only large enough to allow easy installation of the conduit.
- H. Patching is to be of the same kind of material as was removed.
- I. The completed patching work shall restore the surface to its original appearance.
- J. Patching of waterproofed surfaces shall render the area of the patching completely waterproofed.
- K. Remove rubble and excess patching materials from the premises.
- L. Raceways and ducts penetrating rated floor, ceiling or wall assemblies shall be properly sealed in accordance with the corresponding Underwriters Laboratories approved method utilizing approved and listed materials.

## 1.18 INTERPRETATION OF DRAWINGS

- A. The Electrical drawings and specifications are complementary each to the other and what may be called for by one shall be as binding as if called for by both. The drawings are diagrammatic and indicate generally the location of outlets, devices, equipment, wiring, etc. Drawings shall be followed as closely as possible; however, all work shall suit the finished surroundings and/or trim.
- B. Do not scale electrical drawings. Refer to the architectural drawings for dimensions.
- C. Where the words “furnish and install” or “provide” are used, it is intended that this contractor shall purchase and install completely any and/or all material necessary and required for this particular item, system, equipment, etc.
- D. Where the words “the Contractor” or “this Contractor” appear in either the Electrical Drawings or Division 26 Specifications, it shall mean the Electrical Contractor.
- E. Any omission from either the drawings or these specifications are unintentional, and it shall be the responsibility of this Contractor to call to the attention of the Architect/Engineer any pertinent omissions before submitting a bid. Complete and working systems are required, whether every small item of material is shown and specified or not.
- F. Where no specific material or equipment type is mentioned, a high quality product of a reputable manufacturer may be used provided it conforms to the requirements of these specifications. These materials shall be listed or labeled by a Third Party Testing Agency accredited by the NCBCC to label electrical equipment.
- G. The electrical drawings show the general arrangement of raceways, equipment, fixtures, and appurtenances and shall be followed as closely as actual building construction and the work of other trades will permit. Some adjustment of routings and installation of conduit, cable tray and devices should be expected. The electrical work shall conform to the requirements shown on all of the drawings. General and Structural drawings shall take precedence over Electrical Drawings. Because of small scale of the electrical drawings, it is not possible to indicate offsets, fittings and accessories which may be required. The Contractor shall investigate the structural and finish conditions affecting the work and shall arrange his work accordingly, providing such fittings and accessories as may be required to meet such conditions, without additional cost to the Owner and as directed by the Architect/Engineer.
- H. Each 3-phase circuit shall be run in a separate conduit unless otherwise shown on the Drawings.
- I. Unless otherwise approved by the Architect/Engineer, conduit shown exposed shall be installed exposed; conduit shown concealed shall be installed concealed.
- J. Where circuits are shown as “home runs” all necessary fittings and boxes shall be provided for a complete raceway installation.
- K. Verify with the Architect/Engineer the exact locations and mounting heights of lighting fixtures, switches and receptacles prior to installation.

- L. Any work installed contrary to or without approval by the Architect/Engineer shall be subject to change as directed by the Architect/Engineer, and no extra compensation will be allowed for making these changes.
- M. The locations of equipment, fixtures, outlets, and similar devices shown on the Drawings are approximate only. Exact locations shall be as approved by the Architect/Engineer during construction. Obtain in the field all information relevant to the placing of electrical work and in case of any interference with other work, proceed as directed by the Architect/Engineer and furnish all labor and materials necessary to complete the work in an approved manner.
- N. Surface mounted panel boxes, junction boxes, conduit, etc., shall be supported by spacers to provide a clearance between wall and equipment.
- O. Circuit layouts are not intended to show the number of fittings, or other installation details. Furnish all labor and materials necessary to install and place in satisfactory operation all power, lighting, and other electrical systems shown. Additional circuits shall be installed wherever needed to conform to the specific requirements of equipment.
- P. All connections to the equipment shall be made as required, and in accordance with the approved shop and setting drawings.
- Q. Redesign of electrical work, which is required due to the Contractor's use of an alternate item, arrangement of equipment and/or layout other than specified herein, shall be done by the Contractor at the Contractor's expense. Redesign and detailed plans shall be submitted to the Architect/Engineer for approval. No additional compensation will be provided for changes in the work, either the Electrical Contractor's or others, caused by such redesign.
- R. All floor mounted electrical equipment shall be placed on 4-inch thick concrete housekeeping pads. Edges shall be chamfered.

#### 1.19 SIZE OF EQUIPMENT

- A. Investigate each space in the structure through which equipment must pass to reach its final location. If necessary, the manufacturer shall be required to ship his materials in sections sized to permit passing through such restricted areas in the structure.
- B. The equipment shall be kept upright at all times. When equipment has to be tilted for ease of passage through restricted areas during transportation, the manufacturer shall be required to suitably brace the equipment, to insure that the tilting does not impair the functional integrity of the equipment.

#### 1.20 RECORD DRAWINGS

- A. As the work progresses, legibly record all field changes on one set of project contract drawings, herein after called the "record drawings".
- B. Record drawings shall accurately show the installed condition of the following items:
  - 1. Power distribution one-line diagram(s).

2. Panel schedule(s).
3. Control wiring diagram(s).
4. Service, feeder, branch circuit conduit and conductor sizes.

#### 1.21 GUARANTEE

The Contractor shall guarantee the materials and workmanship covered by these drawings and specifications for a period of one year from the date of acceptance by the Owner. The Contractor shall repair and/or replace any parts of any system that may prove to be defective at no additional cost to the Owner within the guarantee period. All equipment warranties shall be as specified and included in the Contract Documents.

#### 1.22 PHASING OF THE WORK

The Electrical Contractor shall schedule his work as described in the relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.

#### 1.23 ALTERNATE BIDS

Alternate bid items are described in relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.

PART 2 - PRODUCTS Not used.

PART 3 - EXECUTION Not used.

END OF SECTION 260500

## SECTION 260519 - BUILDING WIRE AND CABLE

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Building wire and cable.
- B. Wiring connectors and connections.

## 1.2 RELATED SECTIONS

- A. Section 260533 - Conduit.
- B. Section 260534 - Boxes.
- C. Section 260553 - Identification.

## 1.3 REFERENCES

- A. ANSI/NFPA 70 - National Electrical Code.
- B. NECA Standard of Installation (National Electrical Contractors Association).

## 1.4 SUBMITTALS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog information showing dimensions, ratings, colors, and configurations.
- C. Test Reports: Indicate procedures and values obtained.
- D. Manufacturer's Installation Instructions: Indicate application conditions and limitations of use stipulated by product testing agency specified under Regulatory Requirements.

## 1.5 QUALIFICATIONS

- A. Manufacturer: Company specializing in manufacturing products specified in this Section with minimum three years documented experience.

## 1.6 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

1.7 PROJECT CONDITIONS

- A. All wire and cable shall be installed in conduit. This includes all power wiring; fire alarm, sound and communications wire and cable (unless noted otherwise); HVAC control cable; etc.
- B. Verify that field measurements are as shown on Drawings.
- C. Conductor sizes are based on 75° C. copper.
- D. Wire and cable routing shown on Drawings is approximate unless dimensioned. Route wire and cable as required to meet Project Conditions.
- E. Where wire and cable routing is not shown, and destination only is indicated, determine exact routing and lengths required.

1.8 COORDINATION

- A. Coordinate Work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

PART 2 - PRODUCTS

2.1 BUILDING WIRE AND CABLE

- A. Description: Single conductor insulated building wire.
- B. Conductor: Copper. Solid and stranded as specified below. Minimum #12 AWG, maximum 500 KCMil.
- C. Insulation/Voltage Rating: 600 volts.
- D. Insulation: Dual-rated THHN/THWN or XHHW.
- E. Color Coding:
 

	120/240 volts and 208/120 volts	<u>480/277 volts</u>
Phase A -	Black	Brown
Phase B -	Red	Orange
Phase C -	Blue	Yellow
Neutral -	White	Gray
Ground -	Green	Green

2.2 WIRING CONNECTORS AND CONNECTIONS

- A. Conductors shall be installed continuous from outlet to outlet with no splicing except within outlet or junction boxes, troughs and gutters. Make splices, taps, and terminations to carry full ampacity of conductors with no perceptible temperature rise.
- B. Use mechanical connectors for copper conductor splices and taps, 8 AWG and larger, except main grounding conductors, which shall be terminated with compression lugs. Tape un-

insulated conductors and connector with electrical tape to 150 percent of insulation rating of conductor or use UL-approved insulating covers.

- C. Use insulated spring wire connectors with plastic caps for copper conductors, 10 AWG and smaller, splices and taps in junction boxes, outlet boxes and lighting fixtures, Ideal “wirenuts” or 3M Company “Scotchlock”. “Push wire” type connectors are not acceptable.
- D. “Sta-Kon” or other permanent type crimp connectors shall not be used for branch circuit connections.
- E. Joints in stranded conductors shall be spliced by approved mechanical connectors and gum rubber tape or friction tape. Solderless mechanical connectors for splices and taps, provided with U.L approved insulating covers, may be used instead of mechanical connectors plus tape.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Verify that interior of building has been protected from weather.
- B. Verify that mechanical work likely to damage wire has been completed.
- C. Verify that raceway installation is complete and supported.

#### 3.2 PREPARATION

- A. Completely and thoroughly swab raceway before installing wire.

#### 3.3 WIRING METHODS

- A. Concealed Dry Interior Locations: Use only building wire in raceway.
- B. Exposed Dry Interior Locations: Use only building wire in raceway.
- C. Above Accessible Ceilings: Use only building wire in raceway.
- D. Wet or Damp Interior Locations: Use only building wire in raceway.
- E. Exterior Locations: Use only building wire in raceway.
- F. Underground Installations: Use only building wire in raceway.
- G. VFC Output Circuits: Type TC-ER cable with braided shield in raceway.

#### 3.4 INSTALLATION

- A. Install products in accordance with manufacturers instructions.
- B. Route wire and cable as required to meet Project Conditions.

- C. Install cable in accordance with the NECA “Standard of Installation”.
- D. Use solid conductor for feeders and branch circuits 10 AWG and smaller, and Class B stranded for larger conductors.
- E. Use conductor not smaller than 12 AWG for power and lighting circuits.
- F. Use conductor not smaller than 14 AWG for fire alarm and control circuits.
- G. Use 10 AWG conductors for 20 ampere, 120 volt branch circuits longer than 75 feet (23 m) or branch circuit homeruns longer than 50 feet.
- H. Pull all conductors into raceway at same time.
- I. Use suitable wire pulling lubricant for building wire 4 AWG and larger.
- J. Neatly train and lace wiring inside boxes, equipment, and panelboards.
- K. Clean conductor surfaces before installing lugs and connectors.
- L. Identify wire and cable under provisions of Section 260553.
- M. Identify each conductor with its circuit number or other designation indicated on Drawings.
- N. Common neutral multiwire receptacle branch circuits are not permitted. Provide separate, individual neutral conductors for receptacle circuits.

### 3.5 FIELD QUALITY CONTROL

- A. Perform field inspection and testing under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Inspect wire for physical damage and proper connection.
- C. Measure tightness of bolted connections and compare torque measurements with manufacturer’s recommended values.
- D. Verify continuity of each branch circuit conductor.
- E. Prior to energizing, feeders, sub-feeders and service conductor cables shall be tested for electrical continuity and short circuits. A copy of these tests shall be sent to the North Carolina State Construction Office through the Architect.

END OF SECTION 260519

## SECTION 260526 - GROUNDING AND BONDING

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Equipment grounding conductors.

## 1.2 REFERENCES

- A. IEEE 142 - Recommended Practice for Grounding of Industrial and Commercial Power Systems.
- B. NETA ATS - Acceptance Testing Specifications for Electrical Power Distribution Equipment and Systems (International Electrical Testing Association).
- C. NFPA 70 - National Electrical Code.

## 1.3 SUBMITTALS FOR REVIEW

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide for grounding electrodes and connections.

## 1.4 SUBMITTALS FOR INFORMATION

- A. Submittals: Submittals for information. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

## 1.5 SUBMITTALS FOR CLOSEOUT

- A. Contract Closeout: Procedures for submittals as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

## 1.6 QUALIFICATIONS

Manufacturer: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience, and with service facilities within 100 miles of Project.

## 1.7 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.

- B. Products: Listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

## PART 2 -PRODUCTS

### 2.1 MECHANICAL CONNECTORS

Material: Cast bronze, brass, or plain malleable iron. Ground clamps shall not be fabricated from aluminum or any aluminum alloy.

### 2.2 WIRE

Material: Stranded copper sized per NEC requirements.

## PART 3 -EXECUTION

### 3.1 EXAMINATION

Coordination and Meetings: Verify existing conditions prior to beginning work as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.

### 3.2 INSTALLATION

- A. Quality Control: Manufacturer's instructions shall be followed as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Provide bonding to meet Regulatory Requirements.
- C. Provide separate, insulated conductor within each feeder and branch circuit raceway.
- D. Equipment Grounding Conductor: The raceway system shall not be relied on for ground continuity. A green grounding conductor, properly sized per the NEC (Table 250-122) shall be run in all raceways. Terminate each end on suitable lug, bus, or bushing. Exceptions are as follows:
  - 1. Raceways for telecommunications.
  - 2. Raceways for data.
  - 3. Raceways for audio conductors.
  - 4. Services.
- E. Equipment grounding continuity shall be maintained through flexible conduit as required in previous sections.
- F. Grounding conductors shall be installed as to permit the shortest and most direct path from equipment to ground. All connections to ground conductors shall be accessible for inspection and made with approved solderless connectors, brazed or bolted to the equipment or structure to be grounded. All contact surfaces shall be thoroughly cleaned before connections are made to insure good metal to metal contact.

- G. All equipment housings and/or enclosures, and all non-current carrying metallic parts of electrical equipment, raceway systems, etc., shall be effectively and adequately bonded to ground.
- H. Boxes with concentric, eccentric or over-sized knockouts shall be provided with bonding bushings and jumpers. The jumper shall be sized per the NEC and lugged to the box.
- I. An equipment ground bus shall be installed in each panelboard for terminating equipment grounding conductors.
- J. All wiring devices equipped with grounding connections shall be permanently and securely connected to the enclosure in which they are mounted with a copper grounding jumper.

### 3.3 FIELD QUALITY CONTROL

- A. Quality Assurance: Field inspection, testing and adjusting as required under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Inspect and test in accordance with NETA ATS, except Section 4, or provide for qualified technicians to perform testing according to the manufacturer's recommendations.

END OF SECTION 260526

## SECTION 260529 - SUPPORTING DEVICES

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Conduit and equipment supports.
- B. Anchors and fasteners.

## 1.2 REFERENCES

- A. NECA - National Electrical Contractors Association.
- B. ANSI/NFPA 70 - National Electrical Code.

## 1.3 SUBMITTALS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog data for fastening systems.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, installation, and starting of Product.

## 1.4 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

## PART 2 - PRODUCTS

## 2.1 PRODUCT REQUIREMENTS

- A. Materials and Finishes: Provide adequate corrosion resistance. See Specifications Section 260500, Para. 1.14 for additional hardware corrosion resistance requirements.
- B. Provide materials, sizes, and types of anchors, fasteners and supports to carry the loads of equipment and conduit. Consider weight of wire in conduit when selecting products.
- C. Anchors and Fasteners:
  - 1. Concrete Structural Elements: Use expansion anchors.
  - 2. Steel Structural Elements: Use beam clamps.
  - 3. Concrete Surfaces: Use self-drilling anchors and expansion anchors.

4. Hollow Masonry, Plaster, and Gypsum Board Partitions: Use toggle bolts.
5. Solid Masonry Walls: Use expansion anchors.
6. Sheet Metal: Use sheet metal screws or bolts
7. Wood Elements: Use wood screws.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- A. Install products in accordance with manufacturer's instructions.
- B. Provide anchors, fasteners, and supports in accordance with NECA "Standard of Installation".
- C. Do not fasten supports to pipes, ducts, mechanical equipment, and conduit.
- D. Do not use powder-actuated anchors.
- E. Obtain permission from Architect/Engineer before drilling or cutting structural members.
- F. Fabricate supports from structural steel or steel channel. Rigidly weld members or use hexagon head bolts to present neat appearance with adequate strength and rigidity. Use spring lock washers under all nuts.
- G. Install surface-mounted cabinets and panelboards with minimum of four anchors.
- H. In wet and damp locations use steel channel supports to stand cabinets and panelboards one inch (25 mm) off wall.
- I. Conduits installed on the interior of exterior building walls shall be spaced away from the wall surface a minimum of 1/4 inch (65mm) using "clamp-backs" or struts.
- J. Use sheet metal channel to bridge studs above and below cabinets and panelboards recessed in hollow partitions.

END OF SECTION 260529

## SECTION 260533 - RACEWAYS AND BOXES FOR ELECTRICAL SYSTEMS

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Metal conduit.
- B. Flexible metal conduit.
- C. Liquidtight flexible metal conduit.
- D. Electrical metallic tubing.

## 1.2 RELATED SECTIONS

- A. Section 260534 - Boxes.
- B. Section 260526 - Grounding and Bonding.
- C. Section 260529 - Supporting Devices.
- D. Section 260553 - Electrical Identification.

## 1.3 REFERENCES

- A. ANSI C80.1 - Rigid Steel Conduit, Zinc Coated.
- B. ANSI C80.3 - Electrical Metallic Tubing, Zinc Coated.
- C. ANSI/NEMA FB 1 - Fittings, Cast Metal Boxes, and Conduit Bodies for Conduit and Cable Assemblies.
- D. ANSI/NFPA 70 - National Electrical Code.
- E. NECA "Standard of Installation".

## 1.4 DESIGN REQUIREMENTS

Conduit Size: ANSI/NFPA 70.

## 1.5 SUBMITTALS

- A. Submit under provisions of relevant sections of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide for metallic conduit, flexible metal conduit, liquidtight flexible metal conduit, metallic tubing, nonmetallic conduit, fittings and conduit bodies.

## 1.6 PROJECT RECORD DOCUMENTS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Accurately record actual routing of conduits larger than 2 inches (51 mm).

## 1.7 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

## 1.8 DELIVERY, STORAGE, AND HANDLING

- A. Deliver, store, protect, and handle Products to site under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Accept conduit on site. Inspect for damage.
- C. Protect conduit from corrosion and entrance of debris by storing above grade. Provide appropriate covering.
- D. Protect PVC conduit from sunlight.

## 1.9 PROJECT CONDITIONS

- A. Verify that field measurements are as shown on Drawings.
- B. Verify routing and termination locations of conduit prior to rough-in.
- C. Conduit routing is shown on Drawings in approximate locations unless dimensioned. Route as required to complete wiring system.

## PART 2 - PRODUCTS

## 2.1 CONDUIT REQUIREMENTS

- A. Size: Conduit shall be sized in accordance with the latest edition of the NEC unless shown otherwise, with minimum conduit size being ½ inch, except homeruns minimum size shall be ¾". Flexible metal and watertight ("sealtite") conduit in size ½ inch and larger are acceptable for motor, appliance and fixture connections provided green ground wire is installed (see Section 260526) and NEC is followed.
- B. All conduit will be provided with insulated throat.
- C. Outdoor Locations, Above Grade: Use rigid steel conduit.
- D. Wet and Damp Locations: Use rigid steel conduit.

- E. Dry Locations:
  - 1. Concealed: Use rigid steel conduit, intermediate metal conduit or electrical metallic tubing. EMT may be utilized as permitted by the NEC, with the following restrictions. EMT shall not be installed:
    - a. where tubing, couplings, elbows and fittings would be in direct contact with the earth.
    - b. underground (in/below slab-on-grade or in earth).
    - c. any location outdoors where the tubing, etc., would be subjected to the elements.
    - d. where subject to severe corrosive influence.
    - e. where subject to severe physical damage.
  - 2. Exposed: Use rigid steel conduit, EMT, or intermediate metal conduit.

## 2.2 METAL CONDUIT

- A. Rigid Steel Conduit: ANSI C80.1.
- B. Plastic-Coated Rigid Steel Conduit: ANSI C80.1, 40 mil PVC coating.
- C. Intermediate Metal Conduit (IMC): Rigid steel.
- D. Fittings and Conduit Bodies: ANSI/NEMA FB 1; material to match conduit with all steel fittings.

## 2.3 FLEXIBLE METAL CONDUIT

- A. Description: Interlocked steel construction.
- B. Fittings: ANSI/NEMA FB 1, steel.

## 2.4 LIQUIDTIGHT FLEXIBLE METAL CONDUIT

- A. Description: Interlocked steel construction with PVC jacket.
- B. Fittings: ANSI/NEMA FB 1, steel or nonmetallic type.

## 2.5 ELECTRICAL METALLIC TUBING (EMT)

- A. Description: ANSI C80.3; galvanized tubing.
- B. Fittings and Conduit Bodies: ANSI/NEMA FB 1; steel or malleable iron, compression type, insulated throat.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- A. Circuiting is shown schematically. Exact routing of branch circuits may be varied to suit building construction; however, the combination of circuits within raceways and panelboard connections shall not be changed from those shown on the drawings.

- B. Raceways shall be installed concealed in finished areas. Where construction does not permit concealed raceways and where indicated on the drawings, raceways shall be run exposed. Exposed raceways shall be run parallel to, or at a right angle with the building walls. Route conduit installed above accessible ceilings parallel and perpendicular to walls.
- C. Where any run of rigid conduit may change to a run of EMT or vice-versa, each change shall be made in a junction or outlet box with each conduit terminated separately therein. Rigid conduit to EMT (or vice-versa) adapters shall not be permitted.
- D. Install conduit in accordance with NECA "Standard of Installation".
- E. Arrange conduit to maintain headroom and present neat appearance.
- F. Maintain adequate clearance between conduit and piping.
- G. Maintain 12 inch (300 mm) clearance between conduit and surfaces with temperatures exceeding 104 degrees F (40 degrees C).
- H. Cut conduit square using saw or pipecutter and de-burr cut ends.
- I. Bring conduit to shoulder of fittings; fasten securely.
- J. Use conduit hubs or sealing locknuts to fasten conduit to sheet metal boxes in damp and wet locations and to cast boxes.
- K. Install no more than equivalent of three 90-degree bends between boxes. Use conduit bodies to make sharp changes in direction, as around beams. Use factory elbows, or hydraulic one-shot bender, to fabricate bends in metal conduit larger than 2 inch size.
- L. Avoid moisture traps; provide junction box with drain fitting at low points in conduit system.
- M. Provide suitable fittings to accommodate expansion and deflection where conduit crosses, control and expansion joints.
- N. Provide suitable pull string in each empty conduit except sleeves and nipples.
- O. Use suitable caps to protect installed conduit against entrance of dirt and moisture.
- P. The raceway system shall not be relied on for grounding continuity. Ground and bond conduit under provisions of Section 260526.
- Q. Identify conduit under provisions of Section 260553.
- R. The use of "LB's" shall be limited where possible. Where necessary to use "LB's" sized above 2 inch, mogul units shall be installed.
- S. Where concentric, eccentric or over-sized knockouts are encountered, a grounding type insulated bushing shall be provided.
- T. Fasten conduit supports to building structure and surfaces under provisions of Section 260529.

- U. Arrange supports to prevent misalignment during wiring installation.
- V. Support conduit using coated steel or malleable iron straps, lay-in adjustable hangers, clevis hangers, and split hangers.
- W. Group related conduits; support using conduit rack. Construct rack using steel channel; provide space on each for 25 percent additional conduits.
- X. Do not support conduit with wire or perforated pipe straps. Remove wire used for temporary supports.
- Y. Do not attach conduit to ceiling support wires.
- Z. All metallic raceways entering or leaving panelboards (branch circuits less than 30 amperes in lighting and appliance branch circuit panelboards excepted), switchboards, transfer switches, enclosed circuit breakers, safety switches, transformers, etc. shall be provided with insulated grounding and bonding bushings and each separate piece of raceway shall be individually bonded to the equipment ground bus or metallic enclosure, as applicable, by means of copper conductor sized in accordance with the National Electrical Code.
- AA. The term “fittings” includes couplings, connectors, offsets, LBs, etc.
- BB. No pressure cast (pot metal) fittings or conduit bodies shall be allowed.
- CC. Outlets, junction, taps, etc., on exposed rigid metal conduit shall be cast metal conduit fittings or cast metal boxes of the type and size appropriate for the location. Sheet steel outlet boxes shall not be permitted on exposed raceway runs except at or near a ceiling for interior construction.
- DD. EMT couplings and terminations shall be made utilizing steel-plated hexagonal compression connectors. No set screw or indented type fittings shall be utilized.
- EE. IMC and GRC shall terminate with either a double locknut / bushing set, or in a threaded hub.
- FF. Conduit couplings for IMC and GRC shall be in accordance with the NEC.
- GG. Raceways that penetrate outside walls, ceilings from conditioned space or other similar condition shall be effectively sealed to prevent condensation from infiltrating humid air.
- HH. EMT conduit provided below roof deck shall be installed 1 1/2 inches away from the deck to allow for screws not to penetrate the EMT conduit during reroofing.
- II. Conduits, JBs, Troughs, any enclosure when mounted outside on the walls, shall be off the walls by one inch.

### 3.2 INTERFACE WITH OTHER PRODUCTS

- A. Install conduit to preserve fire resistance rating of partitions and other elements, using materials and methods under the provisions of Division 7.
- B. Route conduit through roof openings for piping and ductwork or through suitable roof jack with pitch pocket. Coordinate location with roofing installation specified under Division 7.

END OF SECTION 260533

## SECTION 260534 - BOXES

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Wall and ceiling outlet boxes.
- B. Pull and junction boxes.

## 1.2 RELATED SECTIONS

- A. Section 260529 – Supporting Devices.

## 1.3 REFERENCES

- A. NECA - Standard of Installation.
- B. NEMA FB 1 - Fittings and Supports for Conduit and Cable Assemblies.
- C. NEMA OS 1 - Sheet-steel Outlet Boxes, Device Boxes, Covers, and Box Supports.
- D. NEMA 250 - Enclosures for Electrical Equipment (1000 Volts Maximum).
- E. NFPA 70 - National Electrical Code.

## 1.4 SUBMITTALS FOR REVIEW

- A. Submittals: Procedures for submittals. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide manufacturer's catalog information showing dimensions and configurations.

## 1.5 SUBMITTALS FOR CLOSEOUT

- A. Contract Closeout: Submittals for Project closeout. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Record actual locations and mounting heights of outlet, pull, and junction boxes on project record documents.

## 1.6 REGULATORY REQUIREMENTS

- A. Conform to requirements of NFPA 70.
- B. Provide Products listed and classified by testing firm acceptable to the authority having jurisdiction as suitable for the purpose specified and indicated.

## PART 2 - PRODUCTS

### 2.1 OUTLET BOXES

- A. Sheet Metal Outlet Boxes (for interior conditioned spaces only): NEMA OS 1, galvanized steel.
  - 1. Junction, switch, receptacle and outlet boxes for interior use in dry locations shall be zinc coated or cadmium plated sheet steel, 4" square and 2-1/8" deep, unless otherwise indicated on the contract drawings. Smaller and shallower outlet boxes will be permitted only by special permission of the Architect/Engineer where such boxes are necessary due to structural conditions encountered. Where larger junction boxes are required, they shall be fabricated from No. 10, 12, 14 or 16 gauge sheet steel as required by the Underwriters Laboratories, Inc., and galvanized after fabrication. All junction boxes shall have screw fastened covers. Outlet boxes shall be provided with extension plaster rings where required by structural and finish conditions. Sheet steel boxes shall be as manufactured by Appleton, Racor, Steel City or Spring City.
  - 2. Luminaire and Equipment Supporting Boxes: Rated for weight of equipment supported; include 2 inch (13 mm) male fixture studs where required.
  - 3. Concrete Ceiling Boxes: Concrete type.
- B. Cast Boxes (for all exterior and exposed unconditioned spaces): NEMA FB 1, Type FD, cast ferrous alloy. Provide gasketed cover by box manufacturer. Provide threaded hubs. Cast boxes shall be by Crouse-Hinds, Appleton, O. Z. Gedney or Killark.
- C. Wall Plates for Finished Areas: As specified in Section 16140.

### 2.2 PULL AND JUNCTION BOXES

Sheet Metal Boxes: NEMA OS 1, galvanized steel.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

Verify locations of outlets prior to rough-in.

### 3.2 INSTALLATION

- A. Install boxes in accordance with NECA "Standard of Installation".

- B. Install in locations as shown on Drawings, and as required for splices, taps, wire pulling, equipment connections and compliance with regulatory requirements.
- C. Set wall mounted boxes at elevations to accommodate mounting heights indicated and specified in section for outlet device. Boxes are shown on Drawings in approximate locations unless dimensioned. Adjust box location up to 10 feet (3 m) if required to accommodate intended purpose. Install pull boxes and junction boxes above accessible ceilings and in unfinished areas only. Install boxes to preserve fire resistance rating of partitions and other elements, using approved materials and methods. Coordinate mounting heights and locations of outlets mounted above counters, benches, and backsplashes. Use flush mounting outlet box in finished areas. Use stamped steel bridges to fasten flush mounting outlet box between studs.

### 3.3 ADJUSTING

- A. Contract Closeout: Adjust installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Adjust flush-mounting outlets to make front flush with finished wall material.
- C. Install knockout closures in unused box openings.

### 3.4 CLEANING

- A. Contract Closeout: Clean installed work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Clean interior of boxes to remove dust, debris, and other material.
- C. Clean exposed surfaces and restore finish.

END OF SECTION 260534

## SECTION 260553 - ELECTRICAL IDENTIFICATION

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

- A. Nameplates and labels.
- B. Wire and cable markers.
- C. Conduit markers.

## 1.2 RELATED SECTIONS

Division 9: Painting.

## 1.3 REFERENCES

ANSI/NFPA 70 - National Electrical Code.

## 1.4 SUBMITTALS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide catalog data for nameplates, labels, and markers.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under regulatory requirements. Include instructions for storage, handling, protection, examination, preparation and installation of Product.

## 1.5 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

## PART 2 - PRODUCTS

## 2.1 NAMEPLATES AND LABELS

- A. Nameplates: Engraved three-layer laminated plastic as follows:

Furnish and install engraved laminated phenolic nameplates for all electrical equipment supplied under this contract for identification of system, equipment controlled or served, phase, voltage, ampacity, etc. Nameplates shall be securely attached to equipment with stainless steel screws, and shall identify by name the equipment controlled, attached, etc. Embossed, self

adhesive plastic tape is not acceptable for marking equipment. Nameplate material colors shall be:

1. Blue surface with white core for all 120/208 volt equipment.
2. Black surface with white core for 277/480 volt equipment.
3. Bright red surface with white core for all equipment related to fire alarm system.
4. Dark red (burgundy) surface with white core for all equipment related to Security.
5. Green surface with white core for all equipment related to "emergency" systems.
6. Orange surface with white core for all equipment related to telephone systems.
7. Brown surface with white core for all equipment related to data systems.
8. White surface with black core for all equipment related to paging systems.
9. Purple surface with white core for all equipment related to TV systems.

B. Locations:

1. Each electrical distribution and control equipment enclosure (safety switches, panelboards, transformers, etc.)
2. Communication cabinets.
3. Pull and splice boxes.

C. Letter Size: Letters shall be a minimum of 1/2 inch (13 mm) high.

## 2.2 WIRE MARKERS

A. Description: Split sleeve type wire markers or approved equivalent.

B. Locations: Each conductor at panelboard gutters, pull boxes, outlet and junction boxes, and each load connection.

C. Legend:

1. Power and Lighting Circuits: Branch circuit or feeder number as indicated on drawings.
2. Control Circuits: Control wire number as indicated on schematic and interconnection diagrams on drawings.

## 2.3 CONDUIT, RACEWAY AND BOX MARKING

Paint visible surfaces of exposed junction and outlet boxes and covers of raceway systems above lay-in and other accessible ceilings. Paint all boxes and covers before installation. Paint exposed conduit and raceways at ten foot minimum intervals with a 6 inch wide band in accordance with the color scheme outlined above. Mark conduits at junction boxes above accessible ceilings with the panelboard and circuit numbers of the circuits contained in the raceway using a permanent black marking pen.

## PART 3 - EXECUTION

### 3.1 PREPARATION

Degrease and clean surfaces to receive nameplates and labels.

### 3.2 APPLICATION

A. Install nameplate parallel to equipment lines.

- B. Secure nameplate to equipment front using self tapping stainless steel screws, lockwashers and acorn nuts as shown on the Drawings.
- C. Secure nameplate to inside surface of door on panelboard that is recessed in finished locations.
- D. All empty conduit runs and conduit with conductors for future use shall be identified for use and shall indicate where they terminate. Identification shall be by tags with string or wire attached to conduit or outlet.
- E. Update all existing panelboard directories where changes are made. Provide new panel schedule cards as required to maintain legibility.
- F. Install adhesive backed labels and nameplates only when ambient temperature and humidity conditions for adhesive use are within range recommended by manufacturer.

END OF SECTION 260553

## SECTION 260580 - EQUIPMENT WIRING SYSTEMS

## PART 1 - GENERAL

## 1.1 SECTION INCLUDES

Electrical supply for, and connections to, equipment specified under other Divisions.

## 1.2 RELATED DIVISIONS AND SECTIONS

- A. Division 23: Heating Ventilating and Air Conditioning.
- B. Specification 260533 – Conduit.
- C. Specification 260519 - Building Wire and Cable.
- D. Specification 260534 – Boxes.
- E. Specification 260526 - Grounding and Bonding.

## 1.3 REFERENCES

- A. NEMA WD 1 - General Purpose Wiring Devices.
- B. NEMA WD 6 - Wiring Device Configurations.
- C. ANSI/NFPA 70 - National Electrical Code.

## 1.4 SUBMITTALS

- A. Submit under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Product Data: Provide wiring device manufacturer's catalog information showing dimensions, configurations, and construction.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, installation, and starting of Product.

## 1.5 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

- C. Where electrical wiring is required by trades other than covered by Division 26, specifications for that section shall refer to same wiring materials and methods as specified under Division 26.

#### 1.6 COORDINATION

- A. Coordinate work under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Obtain and review shop drawings, product data, and manufacturer's instructions for equipment furnished under other sections.
- C. Determine connection locations and requirements.
- D. Sequence rough-in of electrical connections to coordinate with installation schedule for equipment.
- E. Sequence electrical connections to coordinate with start-up schedule for equipment.

### PART 2 - PRODUCTS

#### 2.1 CORDS AND CAPS

- A. Attachment Plug Construction: Conform to NEMA WD 1.
- B. Configuration: NEMA WD 6; match receptacle configuration at outlet provided for equipment.
- C. Cord Construction: ANSI/NFPA 70, Type SO multiconductor flexible cord with identified equipment grounding conductor, suitable for use in damp locations.
- D. Size: Suitable for connected load of equipment, length of cord, and rating of branch circuit overcurrent protection.

### PART 3 - EXECUTION

#### 3.1 EXAMINATION

- A. Verify conditions under provisions of the General and Supplemental General Conditions and Division 1 Specifications Sections.
- B. Verify that equipment is ready for electrical connection, wiring, and energization.

#### 3.2 ELECTRICAL WORK IN CONNECTION WITH OTHER CONTRACTS

- A. The Electrical Contractor shall provide a source of power for mechanical, plumbing, sprinkler, elevator, General Contractor-furnished and Owner-furnished equipment shown on the Drawings. Provide pigtails, flexible connections, conductors, raceways, circuit breakers, safety switches, receptacles, junction boxes, panelboards and/or wiring troughs as detailed in this section and/or as shown on the Drawings.

- B. Safety switches, fuses, variable speed drives, magnetic motor starters, magnetic motor starter overload elements, control devices and sensors and control wiring and control raceways for such equipment will be provided and installed by the contractor providing the equipment. The locations of local disconnecting means furnished by other divisions are shown on the respective division's Drawings. Coordinate exact locations with the contractor providing the equipment. Coordinate and verify all electrical requirements, connections, phasing and rotation, overcurrent and overload protective device sizes with the Contractor providing the equipment or the Owner in the case of Owner-furnished equipment. See other specifications divisions for further explanation of contractor responsibility. Do not apply power to equipment without the permission of the contractor providing the equipment.
- C. General Contractor Provided Equipment: The Electrical Contractor shall provide a power source adjacent to equipment provided by the General Contractor. Final connections to this equipment shall be provided by the Electrical Contractor. Coordinate exact locations and requirements with the General Contractor.
  - 1. Projection Screens: The Electrical Contractor shall furnish and install a junction box and disconnect switch adjacent to each projection screen and make power connections to the screen power terminals. The Electrical Contractor shall also install and wire screen position switches provided by the General Contractor. Provide connections as required and coordinate exact locations and configurations with the General Contractor and the projection screen vendor. Final connections to the equipment shall be by the Electrical Contractor in cooperation with the General Contractor.
- D. Owner Provided Equipment: The Electrical Contractor shall provide a power source adjacent to equipment provided by the Owner. Coordinate exact locations and requirements with the General Contractor. Final connection to the equipment will be provided by the Electrical Contractor. Provide receptacle configurations and/or provide direct connection as required by equipment and coordinate exact locations and configurations with the Owner. Do not apply power to equipment without the permission of the Owner.

### 3.3 ELECTRICAL CONNECTIONS

- A. Make electrical connections in accordance with equipment manufacturer's instructions.
- B. Make conduit connections to equipment using flexible conduit. Use liquidtight flexible conduit with watertight connectors in damp or wet locations.
- C. Make wiring connections using wire and cable with insulation suitable for temperatures encountered in heat producing equipment.
- D. Provide receptacle outlet where connection with attachment plug is indicated. Provide cord and cap where field-supplied attachment plug is indicated.
- E. Provide suitable strain-relief clamps and fittings for cord connections at outlet boxes and equipment connection boxes.
- F. Install disconnect switches, controllers, control stations, and control devices as indicated.
- G. Modify equipment control wiring with terminal block jumpers as indicated.
- H. Provide interconnecting conduit and wiring between devices and equipment where indicated.

END OF SECTION 260580