

Addendum No. 1

WEST BRUNSWICK HIGH SCHOOL - NEW BUILDING AND RENOVATION

Shallotte, North Carolina

DSP #: 100

DPI School #: 1167

BMG Project #: 2019083.00

May 4, 2020

The following items supplement, change, delete or add to the Construction Documents as though repeated in full therein. All general conditions, special conditions, etc., as originally specified shall apply to these items.

- 1. PROJECT MANUAL:** The following specification(s) have been added, revised or deleted, and are attached to this addendum in PDF format:

- | | |
|----------------------|--|
| a. SECTION 078443 | JOINT FIRESTOPPING. DELETED installer qualification. |
| b. SECTION 081113 | HOLLOW METAL DOORS AND FRAMES. REVISED items in red text. |
| c. SECTION 092216 | NON-STRUCTURAL METAL FRAMING. REVISED items in red text. |
| d. SECTION 092900 | GYPSUM BOARD. REVISED items in red text. |
| e. SECTION 101419 | DIMENSIONAL LETTER SIGNAGE. ADDED new section. |
| f. SECTION 101423 | PANEL SIGNAGE. REVISED items in red text. |
| g. SECTION 123216 | MANUFACTURED PLASTIC-LAMINATE-CLAD CASEWORK.
REVISED items in red text. |
| h. SECTION 123553.19 | WOOD LABORATORY CASEWORK. REVISED items in red text. |
| i. SECTION 123600 | COUNTERTOPS. REVISED items in red text. |
| j. SECTION 233113 | METAL DUCTS. REVISED items in red text. |
| k. SECTION 275116 | INTERCOM / PUBLIC ADDRESS SYSTEMS. REVISED items in red
text. |
| l. SECTION 323113 | CHAIN LINK FENCES AND GATES. REVISED items in red text. |

- 2. DRAWINGS:** The following drawing(s) have been added, revised or deleted, and are attached to this addendum in PDF format:

CLASSROOM BUILDING:

- | | | |
|----------|---------|-----------|
| a. C-2.3 | l. S202 | w. P201 |
| b. C-2.4 | m. S203 | x. P401 |
| c. C-2.5 | n. S301 | y. P502 |
| d. C-2.6 | o. S401 | z. M601 |
| e. C-3.0 | p. S501 | aa. MH101 |
| f. C-3.1 | q. A001 | bb. MH102 |
| g. C-4.0 | r. A102 | cc. E101 |
| h. C-5.0 | s. A303 | dd. E502 |
| i. L-1.0 | t. A603 | ee. E601 |
| j. S101 | u. A701 | ff. E602 |
| k. S201 | v. P101 | |

ADDENDUM NO. 1

WEST BRUNSWICK HIGH SCHOOL - NEW BUILDING AND RENOVATION

2019083.00

CAFETERIA:

a. C-2.3	i. L-1.0	q. A401
b. C-2.4	j. S101	r. A402
c. C-2.5	k. S201	s. E101
d. C-2.6	l. S301	t. E102
e. C-3.0	m. A101	u. E201
f. C-3.1	n. A201	v. E601
g. C-4.0	o. A301	
h. C-5.0	p. A302	

ROTC:

a. G001	h. C-4.0	o. A201
b. C-2.3	i. C-5.0	p. A302
c. C-2.4	j. L-1.0	q. A501
d. C-2.5	k. S101	r. M101
e. C-2.6	l. S201	s. E101
f. C-3.0	m. A001	t. E201
g. C-3.1	n. A101	

CLASSROOM 403 RENOVATION:

- a. P101

3. ITEMS FOR CLARIFICATION:

- a. Cafeteria: Add signage for room 482 BDA Closet. To match Sign Type A on ROTC.
- b. Classroom Building: South wall of Janitor 919 to be 1-hour rated wall construction
- c. Classroom Building: All walls of Electric 1012 and Storage 1003 to be 1-hour rated wall construction. Doors in these rooms to be 20-minute rated doors.

End of Addendum No. 1