


ELECTRICAL NOTES

1. ELECTRICAL WORK SHALL BE PERFORMED IN ACCORDANCE WITH THE NATIONAL ELECTRICAL CODE AND REQUIREMENTS OF THE LOCAL AUTHORITY HAVING JURISDICTION.
2. PERMITS FOR ELECTRICAL WORK SHALL BE OBTAINED BY AND PAID BY THE ELECTRICAL CONTRACTOR. THE ELECTRICAL CONTRACTOR SHALL PAY FOR ANY ADDITIONAL FEES FOR INSPECTIONS, TESTS, AND OTHER SERVICES AS REQUIRED FOR THE COMPLETION OF THE WORK.
3. THE ELECTRICAL CONTRACTOR AND ANY OF HIS SUBCONTRACTORS SHALL VISIT THE PROJECT SITE TO WITNESS EXISTING CONDITIONS AND BECOME FAMILIAR WITH THE SCOPE OF THE WORK REQUIRED PRIOR TO SUBMITTING PROPOSALS. WORK REQUIRED BY EXISTING JOB CONDITIONS NOT INDICATED ON DRAWINGS SHALL BE INCLUDED IN THE BID.
4. THE DRAWINGS AND SPECIFICATIONS ARE INTENDED TO RESULT IN THE PRODUCTION OF A COMPLETE AND FUNCTIONAL ELECTRICAL SYSTEM. THE ELECTRICAL CONTRACTOR SHALL PROVIDE ALL MATERIAL, LABOR, EQUIPMENT, AND OTHER SERVICES AS NECESSARY TO COMPLETE THE WORK.
5. DISCREPANCIES IN THE DRAWINGS AND SPECIFICATIONS THAT WILL AFFECT THE WORK SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT, ENGINEER, AND/OR OWNER PRIOR TO SUBMITTING PROPOSALS.
6. UNLESS NOTED OTHERWISE, ALL MATERIALS AND EQUIPMENT SHALL BE NEW AND INCLUDE A 3RD PARTY LABEL (I.E.: UL, CSA, ETL, ETC.) LISTING APPROVAL FOR ITS INSTALLED APPLICATION.
7. REVIEW PLANS OF OTHER TRADES FOR COORDINATION OF WORK AND FOR RELATED AND ADJOINING WORK.
8. REVIEW COMPLETE PLAN SET FOR CONSTRUCTION TYPE, FINISHES, HEADROOM, ROOF FINISHES, CEILINGS, ETC. REVIEW COMPLETE PLAN SET FOR PROJECT PHASING AND STAGING. REVIEW COMPLETE PLAN SET FOR WORK COVERED BY ALTERNATE BID ITEMS.
9. COORDINATE DEVICE AND EQUIPMENT MOUNTING HEIGHTS WITH OTHER DISCIPLINE DRAWINGS, CASEWORK DETAILS & SUBMITTALS, EQUIPMENT DETAILS & SUBMITTALS, ETC.
10. PENETRATIONS OF FIRE-RATED WALLS, FLOORS, CEILINGS, AND PARTITIONS SHALL BE FIRE STOPPED IN ACCORDANCE WITH REQUIREMENTS OF THE STATE BUILDING CODE. COORDINATE WORK TO INSURE THAT FIRE STOPPING IS COMPLETED.
11. PENETRATIONS OF SMOKE PARTITIONS SHALL BE SEALED IN ACCORDANCE WITH REQUIREMENTS OF THE STATE BUILDING CODE. COORDINATE WORK TO INSURE THAT SMOKE PARTITION SEALING IS COMPLETED.
12. PENETRATIONS OF EXTERIOR BUILDING WALLS, FLOORS, OR ROOFS SHALL BE SEALED WATERTIGHT. INTERIORS OF RACEWAY PENETRATIONS THROUGH EXTERIOR WALLS SHALL BE SEALED WITH NON-HARDENING ELECTRICAL PUTTY.
13. CUTTING AND PATCHING TO INSTALL DEVICES AND EQUIPMENT SHALL BE PERFORMED WITH FINISHES RESTORED TO THEIR ORIGINAL CONDITION. SUCH WORK SHALL BE COMPLETED TO A DEGREE THAT IS ACCEPTABLE TO THE ARCHITECT, ENGINEER, AND/OR OWNER.
14. SEE SPECIFICATIONS FOR DIVISION OF RESPONSIBILITY FOR PROVIDING DISCONNECTS, STARTERS, DRIVES, ETC. FOR EQUIPMENT SUPPLIED BY OTHER SUBCONTRACTORS.
15. COORDINATE PRECISE LOCATION OF HVAC EQUIPMENT WITH THE MECHANICAL CONTRACTOR.
16. FOR HVAC EQUIPMENT, VERIFY CIRCUIT BREAKER RATINGS, FUSE RATINGS, AND WIRE SIZES. IF RATINGS DIFFER FROM THOSE INDICATED ON THE DRAWINGS, NOTIFY THE ARCHITECT, ENGINEER, AND OWNER FOR DIRECTION. PROVIDE OVERCURRENT PROTECTION IN ACCORDANCE WITH EQUIPMENT MANUFACTURER NAMEPLATE DATA. IF THE EQUIPMENT LISTING LABEL REQUIRES FUSED PROTECTION, ENSURE THAT FUSES IN A FUSED DISCONNECT SWITCH AT THE EQUIPMENT ARE SIZED AS INDICATED ON THE EQUIPMENT LABEL.
17. VERIFY PROPER SIZING OF OVERLOAD DEVICES IN STARTERS BASED ON EQUIPMENT NAMEPLATE DATA.
18. IF HORSEPOWER OR LOAD RATINGS OF EQUIPMENT DIFFER FROM THOSE INDICATED ON THE DRAWINGS, NOTIFY THE ARCHITECT, ENGINEER, AND OWNER FOR DIRECTION.
19. PROVIDE NATIONAL ELECTRICAL CODE REQUIRED CLEARANCES FOR ALL ELECTRICAL EQUIPMENT. COORDINATE RESOLUTION OF CONFLICTS WITH OTHER TRADES.
20. RECEPTACLE, SWITCH, DATA/TELEPHONE OUTLETS SHALL BE FLUSH MOUNTED IN FINISHED SPACES WITH NEW WALLS AND SURFACE MOUNTED IN FINISHED SPACES WITH EXISTING WALLS.
21. WHERE INSTALLED IN PLENUM SPACES, CABLES SHALL BE PLENUM-RATED OR INSTALLED IN METAL RACEWAY.
22. PRIOR TO ORDERING LIGHT FIXTURES, CONTRACTOR SHALL VERIFY TYPE OF CEILING OR WALL BY REVIEW OF ARCHITECTURAL FINISH SCHEDULES AND PROVIDE SUITABLE TRIM AND APPURTENANCES TO MOUNT FIXTURES IN TYPE OF CEILING OR WALL INDICATED.
23. RECESSED LIGHT FIXTURES INSTALLED IN CEILINGS HAVING INSULATION INSTALLED OVER CEILING AND FIXTURES (AS INDICATED IN ARCHITECTURAL PLANS, OR FOUND AS EXISTING CONDITIONS) SHALL BE U.L. RATED FOR DIRECT CONTACT WITH INSULATION.
24. EXIT AND EMERGENCY LIGHTS SHALL BE CONNECTED TO THE NEAREST UNSWITCHED CIRCUIT THAT SERVES LIGHT FIXTURES WITHIN THE SAME SPACE. NO MOUNTING HARDWARE SHALL BE ATTACHED TO ROOF DECKS. ATTACHMENTS SHALL BE MADE TO THE ROOF SUPPORTING STRUCTURE.
25. WHERE WORKING IN EXISTING BUILDINGS, FACILITIES, OR STRUCTURES, PROTECT AND MAINTAIN IN OPERATION EXISTING LIFE SAFETY SYSTEMS, PUBLIC ADDRESS SYSTEMS, ELECTRICAL SYSTEMS, ETC. IF SHUTDOWNS ARE REQUIRED, NOTIFY THE ARCHITECT, ENGINEER, AND OWNER FOR COORDINATION WELL IN ADVANCE OF ANY SYSTEM SHUTDOWN. WHERE AN OUTAGE OF EXTENDED DURATION IS NOT ACCEPTABLE TO THE OWNER, PROVIDE TEMPORARY CONNECTIONS AS REQUIRED TO MAINTAIN SERVICE.
27. WHERE WORKING IN EXISTING BUILDINGS, FACILITIES, OR STRUCTURES; EXISTING ABANDONED CIRCUITS USED TO CONNECT NEW LOADS IN THE SAME AREA SHALL BE CLEARLY IDENTIFIED ON AS-BUILT MARK-UP DRAWINGS WITH REGARD TO PANEL-CIRCUIT AND CIRCUITRY ROUTING CONFIGURATION.
28. ABANDONED CIRCUITRY (RACEWAY & CONDUCTORS) SHALL BE REMOVED IN ITS ENTIRETY FROM ITS SOURCE. ABANDONED LOW VOLTAGE CABLING SHALL BE REMOVED IN ITS ENTIRETY UNLESS OTHERWISE NOTED.
29. PANEL BUS MATERIAL: COPPER.
30. SHARED NEUTRAL CONDUCTORS SHALL NOT BE USED UNLESS SPECIFICALLY INDICATED SO ON HOMERUN CIRCUITRY DESIGNATIONS.
31. PANEL BREAKER CONFIGURATIONS SHALL BE INSTALLED AS INDICATED ON THE PANEL SCHEDULES OR AS NOTED. BREAKER POSITION REVISIONS WILL NOT BE ACCEPTED UNLESS APPROVED IN WRITING BY THE ENGINEER.
32. LOAD CIRCUITS SHALL BE INSTALLED AS INDICATED ON THE DRAWINGS. CIRCUITRY REVISIONS WILL NOT BE ACCEPTED UNLESS APPROVED IN WRITING BY THE ENGINEER.

ABBREVIATIONS

ADA	AMERICAN DISABILITIES ACT
ATF	ABOVE FINISHED FLOOR
AFG	ABOVE FINISHED GRADE
AHU	AIR HANDLER UNIT
AIC	AMPS INTERRUPTING CAPABILITY
BKR	BREAKER
BSPCP	BASEMENT SUMP PUMP CONTROL PANEL
C	CONDUIT
C/B	CIRCUIT BREAKER
CCTV	CLOSED CIRCUIT TELEVISION
CLG	CEILING
CKT	CIRCUIT
COMP	COMPRESSOR
CU	COPPER
DAHU	DUCTLESS AIR HANDLING UNIT
DWG	DUCTLESS HEAT PUMP
DIA	DIAMETER
DWG	DRAWING
EC	ELECTRICAL CONTRACTOR
EMT	ELECTRICAL METALLIC TUBING
ENCL	ENCLOSED
ESPCP	ELEVATOR SUMP PUMP CONTROL PANEL
EXSTG	EXISTING
FACP	FIRE ALARM CONTROL PANEL
G	EQUIPMENT GROUND
GEC	GROUNDING ELECTRODE CONDUCTOR
GFCI	GROUND FAULT CIRCUIT INTERRUPTER
GFI	GROUND FAULT INTERRUPTER
HP	HEAT PUMP
HP	HORSEPOWER
IMC	INTERMEDIATE METAL CONDUIT
K	KILO (THOUSAND)
K	LIGHT EMITTING DIODE
LTD	LIGHTING
LTS	LIGHTS
MC	MECHANICAL CONTRACTOR
MCB	MAIN CIRCUIT BREAKER
MOP	MAIN DISTRIBUTION PANEL
MFR	MANUFACTURER
MLO	MAIN LUG ONLY
MSB	MAIN SWITCHBOARD
N/A	NOT APPLICABLE
NEC	NATIONAL ELECTRICAL CODE
NEMA	NATIONAL ELECTRICAL MANUFACTURERS ASSOC.
NTS	NOT TO SCALE
OTHLAP	OIL TANK HIGH LEVEL ALARM PANEL
P	PHASE OR POLE
PC	PLUMBING CONTRACTOR
PH	PHASE
PLC	PROGRAMMABLE LOGIC CONTROLLER
PNL	PANEL
PVC	POLYVINYL CHLORIDE
REC	RECEPTACLE
RECP	RECEPTACLE
REQ	REQUIRED
RGC	RIGID GALVANIZED CONDUIT
RGS	RIGID GALVANIZED STEEL
S.S.	STAINLESS STEEL
SSAHU	SPLIT SYSTEM AIR HANDLING UNIT
SYS	SYSTEM
S/N	SOLID NEUTRAL
TSP	TWISTED SHIELED PAIR
TYP	TYPICAL
UL	UNDERWRITERS LABORATORY
UNO	UNLESS NOTED OTHERWISE
UNO	UNLESS OTHERWISE NOTED
V	VOLTS
VA	VOLT-AMPS
VFD	VARIABLE FREQUENCY DRIVE
W	WATTS
W	WIRE
W/	WITH
WP	WEATHERPROOF
WSHP	WATER SOURCE HEAT PUMP
XFMR	TRANSFORMER

MISC. ELECTRICAL SYMBOL LEGEND



HAZARDOUS MATERIALS

THE BUILDING SURFACES MAY HAVE LEAD PAINT. ALL CONTRACTORS ARE REQUIRED TO COMPLY WITH OSHA REGULATIONS 29 CFR 1926.62 BY DEVELOPING A COMPLIANCE PLAN. THE PROJECT DOES NOT INCLUDE ABATEMENT OF ALL LEAD BASED TO LEAD CONTAINING PAINT IN THE BUILDING. WHERE NECESSARY, CONTRACTORS CAN USE GENERAL CONTRACTOR'S ENVIRONMENTAL CONTRACTOR TO REMEDIATE A SPOT OR LOCATION WHERE LEAD PAINT INTERFERES WITH CONSTRUCTION WORK. COST OF REMEDIATION WILL BE INVOICED AGAINST THE LEAD REMOVAL ALLOWANCE.

ALL ASBESTOS IS IDENTIFIED AND WILL BE ABATED AS PART OF THE PROJECT. ANY SUSPECTED AREAS MUST BE REPORTED TO THE ARCHITECT AND FURTHER INVESTIGATION WILL BE DONE BY THE ABATEMENT DESIGNER.



WARNING

Maximum Available Fault Current:
20,251 Symmetrical RMS Amperes
Date: 03/27/2020
Based on :
Utility Transformer: 300 kVA (Maximum)
Utility Transformer: 3.5% Impedance (Minimum)
Service Feeder: #400 kCMIL (4 SETS)(Maximum) Copper
Service Feeder Length: 80' (Minimum)
Motor Load: 46 kVA (Maximum)

NOTE:
THE CONTRACTOR SHALL OBTAIN INSTALLED SERVICE TRANSFORMER DATA AND AVAILABLE FAULT CURRENT DATA FROM THE UTILITY COMPANY, FORWARD INFORMATION TO THE ENGINEER FOR ASSESSMENT OF REVISIONS TO THE LABEL DATA.

FAULT CURRENT LABEL FOR SERVICE EQUIPMENT
NO SCALE

ELECTRICAL LOAD SUMMARY

	CONN KVA	CALC KVA		CONN KVA	CALC KVA	
LIGHTING	28.1	35.2	(125%)	21.6	27	(125%)
LARGEST MOTOR	17.5	4.36	(25%)	18	18	(100%)
MOTORS	59.2	59.2	(100%)	HEATING	48.5	48.5 (100%)
RECEPTACLES	45	27.5	(50%-10)	COOLING	38.8	0 (0%)
KITCHEN EQUIPMENT	1	1	(100%)	DIVERSE	186	66.1 (36%)
				TOTAL LOAD	287	
				BALANCED 3-PHASE AMPS	796	

DATA & TELEPHONE OUTLET LEGEND

SYMBOL	DESCRIPTION	MOUNTING	NOTES
AP	DATA OUTLET FOR ACCESS POINT	4" SQUARE BOX MOUNTED 24" ABOVE CEILING	INSTALL (1) CAT 6A CABLE TO IT ROOM. MOUNT OWNER PROVIDED EQUIPMENT AT CEILING OR WALL MOUNTED IF INDICATED. PROVIDE PATCH CORD FROM OUTLET TO EQUIPMENT.
◁	DATA / TELEPHONE OUTLET	REUSE EXISTING BOX AND RACEWAY	CONTRACTOR TO FIELD VERIFY ALL EXISTING LOCATIONS AND CABLE PATHWAYS. CABLE PATHWAYS TO BE REUSED WHERE POSSIBLE. REPLACE EXISTING WIREMOLD IF DAMAGED DURING INSTALLATION OF NEW CABLES. BASE BID: NO WORK. ALTERNATE BID: INSTALL (2) CAT 6 CABLES TO IT ROOM; OTHERWISE, # INDICATES QUANTITY OF CABLES IF > 2
◁ N	DATA / TELEPHONE OUTLET	WALL, 18" AFF UNO; 5" SQUARE, 2.875" DEEP BOX, 64 CUBIC INCHES, WITH CABLE MANAGEMENT POSTS. DESIGN BASIS: STEEL CITY #B2181T SERIES	STUB 1" TO 6" ABOVE CEILING INSTALL (2) CAT 6 CABLES TO IT ROOM; OTHERWISE, # INDICATES QUANTITY OF CABLES IF > 2
□	EQUIPMENT RACK, 19" X 7"	FLOOR	
◁ ELEV	TELEPHONE OUTLET FOR ELEVATOR COMMUNICATION	COORDINATE INSTALLATION LOCATION WITH ELEVATOR VENDOR/INSTALLER	STUB 1" TO 6" ABOVE CEILING INSTALL (1) TELEPHONE CABLE TO IT ROOM

FIRE ALARM LEGEND

SYMBOL	DESCRIPTION	MOUNTING
15	HORN/STROBE, 15 CANDELA	CEILING
15	CONTROL / RELAY MODULE	
15	CONTROL / RELAY MODULE FOR FIRE CURTAIN ACTIVATION	LOCATE WITHIN 3' OF UNIT
15	FIRE ALARM CONTROL PANEL	
15	HEAT DETECTOR	CEILING
15	HORN/STROBE, 15 CANDELA	WALL
15	PULL STATION	WALL
15	SMOKE DETECTOR	CEILING
15	SMOKE DETECTOR	WALL
15	STROBE, 15 CANDELA	WALL

ELECTRICAL SHEET LIST

SHEET NUMBER	SHEET TITLE
E-001	COVER SHEET
ED-101	ELECTRICAL - CRAWL SPACE DEMOLITION PLAN
ED-102	ELECTRICAL - FIRST FLOOR DEMOLITION PLAN
ED-103	ELECTRICAL - SECOND FLOOR DEMOLITION PLAN
ED-104	ELECTRICAL - THIRD FLOOR DEMOLITION PLAN
ED-105	ELECTRICAL - ATTIC DEMOLITION PLAN
E-101	ELECTRICAL - CRAWL SPACE ELECTRIC PLAN
E-102	ELECTRICAL - FIRST FLOOR POWER PLAN
E-103	ELECTRICAL - SECOND FLOOR POWER PLAN
E-104	ELECTRICAL - THIRD FLOOR POWER PLAN
E-105	ELECTRICAL - ATTIC ELECTRIC PLAN
E-112	ELECTRICAL - FIRST FLOOR LIGHTING PLAN
E-113	ELECTRICAL - SECOND FLOOR LIGHTING PLAN
E-114	ELECTRICAL - THIRD FLOOR LIGHTING PLAN
E-122	ELECTRICAL - FIRST FLOOR AUXILIARY SYSTEMS PLAN
E-123	ELECTRICAL - SECOND FLOOR AUXILIARY SYSTEMS PLAN
E-124	ELECTRICAL - THIRD FLOOR AUXILIARY SYSTEMS PLAN
E-501	ELECTRICAL - DETAILS
E-502	ELECTRICAL - DETAILS
E-601	ELECTRICAL - LUMINAIRE SCHEDULE
E-602	ELECTRICAL - PANEL SCHEDULES
E-701	ELECTRICAL - RISER DIAGRAMS

RECEPTACLE LEGEND

SYMBOL	NEMA	VOLTS	DESCRIPTION
BLK HTR	5-20R	120V 1P 2W	DUPLEX, MTD 18" AFF UNO
G	5-20R	120V 1P 2W	POWER FOR GENERATOR BLOCK HEATER
G	5-20R	120V 1P 2W	DUPLEX GFCI, MTD 6" ABOVE COUNTER HEIGHT UNO
G	5-20R	120V 1P 2W	DUPLEX GFCI, MTD 18" AFF UNO
MW	5-20R	120V 1P 2W	DUPLEX GFCI FOR MICROWAVE; VERIFY MICROWAVE TYPE; MOUNT 6" ABOVE COUNTER HEIGHT FOR COUNTER TOP MICROWAVE -OR- MOUNT FLUSH IN BACK OF UPPER CABINET FOR SUSPENDED MICROWAVE.
R	5-20R	120V 1P 2W	DUPLEX FOR REFRIGERATOR; MOUNT 48" AFF UNO. SUPPLY FROM GFCI TYPE C/B.
UCR	5-20R	120V 1P 2W	DUPLEX FOR UNDERCOUNTER REFRIGERATOR; SUPPLY FROM GFCI TYPE C/B; COORDINATE MOUNTING HEIGHT WITH CASEWORK DRAWINGS.
ARA	120V 1P 2W		POWER FOR AREA OF RESCUE ASSISTANCE MASTER CONSOLE
AUX	120V 1P 2W		J-BOX FOR AUXILIARY POWER, MOUNTED 42" AFF UNO
HT	5-20R	120V 1P 2W	POWER FOR HEAT TRACE; COORDINATE EXACT LOCATION AND REQUIREMENTS WITH EQUIPMENT MANUFACTURER.
SC	120V 1P 2W		POWER FOR SMOKE CURTAIN ACTIVATION. COORDINATE LOCATION WITH SMOKE CURTAIN VENDOR.
QUAD	5-20R	120V 1P 2W	QUAD, MTD 18" AFF UNO
BATT CHG	5-20R	120V 1P 2W	POWER FOR GENERATOR BATTERY CHARGER, BATTERY HEATER, & WINDING HEATER
G	5-20R	120V 1P 2W	QUAD GFCI FOR DEHUMIDIFIER, MTD ON FLOOR JOISTS
EWC	5-20R	120V 1P 2W	QUAD ELECTRIC WATER COOLER OUTLET; SUPPLY FROM GFCI TYPE C/B; COORDINATE MTG LOCATION TO CONCEAL OUTLET WHEN COOLER IS INSTALLED.
EXHAUST FAN	120V 1P 2W		EXHAUST FAN; SEE MECHANICAL SCHEDULE. PROVIDE POWER PACK FOR SWITCHING WITH CEILING OCCUPANCY SENSOR.

SWITCH LEGEND

SYMBOL	DESCRIPTION	NOTES
\$	DIMMER SWITCH	RATED FOR VOLTAGE WHERE APPLIED, 20A; MTD 42" AFF UNO
\$	OCCUPANCY SENSOR WALL SWITCH; DIMMER; DUAL TECHNOLOGY	RATED FOR VOLTAGE WHERE APPLIED, 20A; MTD 42" AFF UNO
\$	OCCUPANCY SENSOR WALL SWITCH, SINGLE CKT, DUAL TECHNOLOGY	RATED FOR VOLTAGE WHERE APPLIED, 20A; MTD 42" AFF UNO
\$	OCCUPANCY SENSOR, LOW VOLTAGE, DUAL TECHNOLOGY; CEILING MTD	INCORPORATE POWER PACK FOR CIRCUITRY SWITCHING, SEE WIRING DIAGRAMS
\$	TOGGLE SWITCH, SINGLE POLE	RATED FOR VOLTAGE WHERE APPLIED, 20A; MTD 42" AFF UNO; WHERE USED AS AN EQUIPMENT DISCONNECT, PROVIDE LOCKABLE TYPE COVER.
\$	3-WAY SWITCH	RATED FOR VOLTAGE WHERE APPLIED, 20A; MTD 42" AFF UNO

PA & SECURITY LEGEND

SYMBOL	DESCRIPTION	MOUNTING	NOTES
AREA	AREA OF RESCUE ASSISTANCE MASTER STATION	WALL	PROVIDE MANUFACTURER'S REQUIRED CABLING / CIRCUITRY BETWEEN MASTER & REMOTE STATIONS
AREA	AREA OF RESCUE ASSISTANCE REMOTE STATION	WALL	
SEC	SECURITY CAMERA - EXISTING	WALL / CEILING	BASE BID: NO WORK. ALTERNATE BID: PROVIDE NEW CAT 6 CABLE AND CAMERA. CONTRACTOR TO COORDINATE WITH OWNER FOR SPEC ON NEW POE CAMERAS. PROVIDE \$500 ALLOWANCE FOR NEW CAMERA
CRD	CARD READER	WALL	4" SQUARE BOX RECESSED; STUB 3/4" TO 6" ABOVE CEILING INSTALL (1) CAT 6 CABLE TO DATA ROOM
ESTR	ELECTRIC STRIKE	DOOR FRAME	FOR SINGLE DOOR, PROVIDE 1/2" FLEXIBLE METALLIC CONDUIT CONCEALED IN DOOR FRAME TO JUNCTION BOX MTD ABOVE CEILING.

PENDER COUNTY COURTHOUSE

PENDER COUNTY



101 NORTH THIRD STREET SUITE 500
WILMINGTON, NORTH CAROLINA 28401
TEL. 910.790.9901 FAX 910.790.3111
WWW.LS3P.COM

CHEATHAM & ASSOCIATES, P.A.
CONSULTING ENGINEERS
3412 ENTERPRISE DRIVE
WILMINGTON, NORTH CAROLINA 28405
(910) 452-4210
FAX: (910) 452-4211
OFFICE@CHEATHAMPA.COM
NC LICENSE# C-1073

JOB # 19060



No.	Description	Date
1	Addendum No. 3	04-14-2020

PROJECT: 7702-185550
DATE: 3/29/20
DRAWN BY: KAF/MP5/FMD/CD
CHECKED BY: M. CIARROCCA

ELECTRICAL-
NOTES, LEGENDS,
SHEET LIST, LOAD
SUMMARY

E-001