

HAZARDOUS MATERIALS

THE BUILDING SURFACES MAY HAVE LEAD PAINT. ALL CONTRACTORS ARE REQUIRED TO COMPLY WITH OSHA REGULATIONS 29 CFR 1926.62 BY DEVELOPING A COMPLIANCE PLAN. THE PROJECT DOES NOT INCLUDE ABATEMENT OF ALL LEAD BASED TO LEAD CONTAINING PAINT IN THE BUILDING. WHERE NECESSARY, CONTRACTORS CAN USE GENERAL CONTRACTOR'S ENVIRONMENTAL CONTRACTOR TO REMEDIATE A SPOT OR LOCATION WHERE LEAD PAINT INTERFERES WITH CONSTRUCTION WORK. COST OF REMEDIATION WILL BE INVOICED AGAINST THE LEAD REMOVAL ALLOWANCE.

ALL ASBESTOS IS IDENTIFIED AND WILL BE ABATED AS PART OF THE PROJECT. ANY SUSPECTED AREAS MUST BE REPORTED TO THE ARCHITECT AND FURTHER INVESTIGATION WILL BE DONE BY THE ABATEMENT DESIGNER.

KEYED NOTES:

- 1 CONNECT TO LIGHTING CIRCUIT PREVIOUSLY SERVING SPACE.
- 2 INSTALL NEW LINE VOLTAGE DIMMER SWITCH IN EXISTING BLANK SWITCH LOCATION. CONTRACTOR TO REUSE EXISTING CIRCUITRY TO PENDANT IF AVAILABLE.
- 3 LOCATION OF RELOCATED EXISTING DIMMER SWITCH.
- 4 FED FROM RECEPTACLE CIRCUIT IN THE ELEVATOR PIT. SEE E-101.
- 5 CONNECT EGRESS FIXTURE TO UN-SWITCHED LEG OF EXISTING ROOM CIRCUITRY.

PENDER COUNTY  
COURTHOUSE

PENDER COUNTY



LS3P

101 NORTH THIRD STREET SUITE 500  
WILMINGTON, NORTH CAROLINA 28401  
TEL. 910.790.9901 FAX 910.790.3111  
WWW.LS3P.COM

CHEATHAM & ASSOCIATES, P.A.  
CONSULTING ENGINEERS  
3412 ENTERPRISE DRIVE  
WILMINGTON, NORTH CAROLINA 28405  
(910) 452-4210  
FAX: (910) 452-4211  
OFFICE@CHEATHAMPA.COM  
NC LICENSE# C-1073

JOB # 19060



No.	Description	Date
1	Addendum No. 3	04-14-2020

PROJECT: 7702-185550  
DATE: 3/29/20  
DRAWN BY: KAF/MP5/FMD/CB  
CHECKED BY: M. CIARROCCA

ELECTRICAL-  
FIRST FLOOR  
LIGHTING PLAN

E-112

BID DOCUMENTS

1 ELECTRICAL FIRST FLOOR LIGHTING PLAN  
SCALE: 3/16" = 1'-0"

GRAPHIC SCALE: 3/16" = 1'-0"  
0 2 4 8

