

HAZARDOUS MATERIALS

THE BUILDING SURFACES MAY HAVE LEAD PAINT. ALL CONTRACTORS ARE REQUIRED TO COMPLY WITH OSHA REGULATIONS 29 CFR 1926.62 BY DEVELOPING A COMPLIANCE PLAN. THE PROJECT DOES NOT INCLUDE ABATEMENT OF ALL LEAD BASED TO LEAD CONTAINING PAINT IN THE BUILDING. WHERE NECESSARY, CONTRACTORS CAN USE GENERAL CONTRACTOR'S ENVIRONMENTAL CONTRACTOR TO REMEDIATE A SPOT OR LOCATION WHERE LEAD PAINT INTERFERES WITH CONSTRUCTION WORK. COST OF REMEDIATION WILL BE INVOICED AGAINST THE LEAD REMOVAL ALLOWANCE.

ALL ASBESTOS IS IDENTIFIED AND WILL BE ABATED AS PART OF THE PROJECT. ANY SUSPECTED AREAS MUST BE REPORTED TO THE ARCHITECT AND FURTHER INVESTIGATION WILL BE DONE BY THE ABATEMENT DESIGNER.

KEYED NOTES:

- 1 RELOCATED EXISTING FIRE ALARM DEVICE.
- 2 COORDINATE MOUNTING WITH ARCHITECT. DEVICE SHALL BE FED FROM CRAWL SPACE. **ALTERNATE 500**

SYSTEM INPUTS	CONTROL UNIT ANNUNCIATION				NOTIFICATION				CONTROL			
	A	B	C	D	E	F	G	H	I	J	K	L
1 MANUAL PULL STATIONS	X	X							X	X	X	X
2 SMOKE/HEAT DETECTORS	X	X							X	X	X	X
3 HEAT DETECTOR - ELEVATOR MECH. ROOM	X	X							X	X	X	X
4 SMOKE DETECTOR - ELEVATOR MECH. ROOM	X	X							X	X	X	X
5 SMOKE DETECTOR - PRIMARY FLOOR ELEVATOR LOBBY	X	X							X	X	X	X
6 SMOKE DETECTOR - ALTERNATE FLOOR ELEVATOR LOBBY	X	X							X	X	X	X
7 HEAT DETECTOR - ELEV. PIT	X	X							X	X	X	X
8 SPRINKLER WATERFLOW	X	X							X	X	X	X
9 FIRE PUMP RUNNING	X	X							X	X	X	X
10 HOOD SUPPRESSION SYS. RELEASE	X	X							X	X	X	X
11 FIRE ALARM DRILL BUTTON ACTIVATION	X	X							X	X	X	X
12 SPRINKLER CONTROL VALVE		X	X						X	X		
13 SPRINKLER SYSTEM LOW TEMPERATURE		X	X						X	X		
14 SPRINKLER SYSTEM LOW AIR PRESSURE		X	X						X	X		
15 FIRE PUMP FAILURE TO START		X	X						X	X		

COORDINATE EXISTING FIRE ALARM SYSTEM MATRIX WITH THE ONE INDICATED ABOVE. REPORT ANY CONFLICTS TO THE ARCHITECT/ENGINEER FOR DIRECTION. IT IS NOT THE INTENT TO MODIFY THE EXISTING FIRE ALARM DEVICE MATRIX TO CONFORM TO THIS MATRIX. RATHER TO INCORPORATE THE NEW FIRE ALARM DEVICES INTO THE EXISTING FIRE ALARM MATRIX UNLESS THE EXISTING MATRIX IS NON CODE COMPLIANT OR NOTED OTHERWISE. MATRIX DATA FOR ELEVATOR INPUT/OUTPUTS REFER TO THE NEW ELEVATOR ONLY.

PENDER COUNTY
COURTHOUSE

PENDER COUNTY



LS3P

101 NORTH THIRD STREET SUITE 500
WILMINGTON, NORTH CAROLINA 28401
TEL. 910.790.9901 FAX 910.790.3111
WWW.LS3P.COM

CHEATHAM & ASSOCIATES, P.A.
CONSULTING ENGINEERS
3412 ENTERPRISE DRIVE
WILMINGTON, NORTH CAROLINA 28405
(910) 452-4210
FAX: (910) 452-4211
OFFICE@CHEATHAMPA.COM
NC LICENSE# C-1073

JOB # 19060



No.	Description	Date
1	Addendum No. 3	04-14-2020

PROJECT: 7702-185550
DATE: 3/29/20
DRAWN BY: KAF/MP5/FMD/DB
CHECKED BY: M. CIARRROCCA

ELECTRICAL-
FIRST FLOOR
AUXILIARY
SYSTEMS PLAN

E-122

BID DOCUMENTS