



June 3, 2020

To: Mike Doyle, Monteith Construction, for distribution to Bidders

From: Dogwood Architecture, PC

Re: Addendum #2 for Shell Bid Set of Documents for the Town of Surf City Municipal Complex

The following shows revisions to the documents referenced above. All other terms, conditions, specifications, submittal time and bid date remain unchanged. This Addendum must be acknowledged in relevant bid documents

Description of Addendum:

A2.2 Added portable fire extinguishers and Knox Box. Modified soffit and windows at reception.

A2.3 Added portable fire extinguishers

A2.4 Ceiling heights adjacent to front and side porch altered to accommodate through wall sprinkler heads at porches.

A2.5 Ceiling heights adjacent to side porches altered to accommodate through wall sprinkler heads at porches.

A2.7 Added sill & threshold details

A4.2 Modified flashing details and interior partition types

A4.3 Added soffit details and exterior band board detail

M2 Revisions to clarify the DOAS system

062023 Interior Finished Carpentry Spec: modified shelving boards at storage closets

076200 Sheet Metal flashing & Trim Spec: modified gutter and downspout to be aluminum

081416 Flush Wood Door Spec: modified finish on doors

087100 Door Hardware Spec: modified to allow additional manufacturers

088000 Glazing Spec: removed spandrel glazing



DOGWOOD ARCHITECTURE

SUSTAINABLE MODERN VERNACULAR

Sincerely,

Eric Jabaley, AIA