

**ADDENDUM II**

Date of Addendum: May 21, 2020

Project Name: The Coast Academy

**PROJECT INFORMATION**

- A. Owner: County of Brunswick North Carolina.
- B. Architect: LS3P.
- C. Architect Project Number: 8201-191241.

**NOTICE TO BIDDERS**

- A. This Addendum is issued pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. Attachments within this Addendum include, but may not be limited to, modifications as noted.

**ATTACHMENTS**

- A. This Addendum includes no attachments.

**REVISIONS TO DIVISIONS 02 - 49 SPECIFICATION SECTIONS**

Item II-1. Section 064219, Article 2.5: Add Paragraph D as follows:

- D. Aluminum Trim: Extruded accessories of profiles and dimensions indicated.
  - 1. Manufacturers: Subject to compliance with requirements, provide products by one of the following:
    - a. Fry Reglet Corp.; Reveal/Channel Screed (Basis of Design)
    - b. Gordon, Inc.
    - c. MM Systems Corporation.
    - d. Pittcon Industries.
  - 2. Aluminum: Alloy and temper with not less than the strength and durability properties of ASTM B 221, Alloy 6063-T5.
  - 3. Finish: Corrosion-resistant primer compatible with joint compound and finish materials specified.

Item II-2. Section 089119: Revise as follows:

- 1. Article 1.2 D: Delete article in its entirety.
- 2. Article 2.1 A: Delete article in its entirety.
- 3. Article 3.1: Add Paragraph E to read "Provide fasteners and fastening pattern as recommended by manufacturer and as required to resist wind loads."

END OF ADDENDUM II