

August 10, 2020

ADDENDUM #4

Tri-house HVAC and Central Plant Improvements

This addendum forms a part of the contract documents and modifies the Issued for Bid drawings and project manual dated 07.30.20. The enclosed additions, deletions, corrections, and changes shall be as binding as if incorporated in the bid documents. All General Conditions, Special Conditions, etc. as originally specified shall apply to these items. Acknowledgement of receipt of this addendum will be required as part of the contract agreement.

- Item 1** Sealed proposals will be received by the University of North Carolina at Wilmington in Wilmington, North Carolina, Project Management Department, in the Facilities Administration Building, **Conference Room #1**, up to **1:00 PM** on **Tuesday, August 11, 2020** and immediately thereafter publicly opened and read for the furnishing of labor, material and equipment entering into the construction of Tri-House HVAC and Central Plant Improvements.
- Item 2** **The existing R2 JACE serving the dorms will not be replaced as part of this contract. It will be replaced in a future phase under a separate contract. Refer to attached system architecture diagram for clarity. Note the architecture may be modified slightly as needed during the submittal process.**

CBHF ENGINEERS, PLLC



David M. Hahn, PE

