

REFERENCE			QUESTION	GOVERNMENT RESPONSE	Posted on Amend No.
Page	Section	Para.			
I-615	Notes		Notes call out Dirtt Modular wall systems. Will other manufactures be allowed and if so will a specification be forthcoming .	SEE AMENDMENT	AMEND 0001 AND AMEND 0002
			With the amount of bids and bid packages at camp Lejeune subs are requesting a 2 week extension to be able to bid the project. With the limited supply of subcontractors available for bid it is imperative to get every bid possible for the government.	The Bid Proposal due date will remains Unchanged	AMEND 0002
BID form			Bid form Clins 0002 Option 1 Calls for price to provide best value Furniture, fixtures and equipment FF&E package for the project. 0003 Option item 2 states design and provide the final best value A/V package for the project. 0004 Planned modification Item 1 is a government Estimate modification for FF&E. 0005 Planned modification item 2 is a government Estimate for A/V. The bid form states that Award will be made on the total sum of 0001, 0002, 0003, 0004 and 0005. Is this correct? are 0002 and 0003 the same as 0004 and 0005 except for being best value? Please clarify	CLIN 0002 and 0003 are for the FF&E Designer and AV Designer Services. CLIN 0004 and 0005 is for the purchase of the FF&E and AV packages.	AMEND 0002
			Sheet M401shows Valves but are not labled some look like possible butterfly and some like ball valves could you please clarify?	All valves shown are isolation valves and shall be valve types per RFP specifications.	AMEND 0002
		13 34 19	"Please confirm the roofing metal panels including in the metal building spec section 13 34 19 are in fact suppose to be aluminum and not steel. Metal roof manufactures do not provide aluminum metal panels as part of their assembly".	PEMB is acceptable with aluminum panel enclosure system, see 13 34 19.	AMEND 0002
		CU 102	Sheet CU102 Keynote 15 Sewer Pump. Refer to Mechanical Plans. Actually the Sewer Pump and Valve Box are shown on the Plumbing Plans. Is this correct and if so is the plumber to pick up this section as it is also shown on Civil?	General contrator is responsible for division of work	AMEND 0002
			On the landscape drawings, it is not shown where a meter and backflow preventor is located in order to water the sod and associated vegetation. Please provide a drawing where this is located if needed.	Refer to Specification Sections (Exterior Improvements); Refer to Plumbing Drawing Series.	AMEND 0002
			Will there be a specification for the roof panels coming?	PEMB is acceptable with aluminum panel enclosure system, see 13 34 19.	AMEND 0002
			We do not see the windows that are associated with specification section 08 56 63. Please advise.	See A-401 and A-402, see keynote A56.	AMEND 0002
			Will there be an extension per previous question # 3	The bid proposal due date will remain unchanged.	AMEND 0002
			Because this facility is owned by the United States Federal Government, and is utilized as a Regiment HQ, we understand that Unified Facilities Criteria ("UFC") 3-520-01 and Unified Facilities Guide Specifications (UFGS) Section 26 05 19.00 2.1.3.1 shall apply for purposes of competitive bidding and project execution. To ensure that the project is bid and constructed in accordance with the applicable regulations and requirements, please confirm that UFC 3-520-01 and UFGS 26 05 19.00 2.1.3.1 shall apply to this project. Specifically, please confirm that bidders are permitted to utilize the type(s) of material(s) described in UFC 3-520-01 and UFGS 26 05 19.00 2.1.3.1 applicable to their scope of work despite any potentially contradictory provisions in the design plans and specifications. Wayne J. Griffin Electric, Inc. requests that you advise us in writing by issuing an addendum to clarify these issues. A timely response will ensure an accurate and complete bid. Thank you for your immediate attention in this crucial matter. If you have any questions or need further information, please do not hesitate to contact me at (508) 306-5480. I look forward to discussing the project with you in the near future. James Burt, Estimator - Wayne J. Griffin Electric, Inc. 116 Hopping Brook Road, Holliston, MA 01746 JBurt@WJGEI.com	Bid per RFP.	AMEND 0002
			Due to the subcontractors market with other bids and now with the upcoming Hurricane we are requesting a time extention of 2 weeks, Please	The bid proposal due date will remain unchanged.	AMEND 0002
			Please consider releasing all PPIs submitted by other firms for consideration by all bidders.	All contractor PPIs are responded to and incorporated into the appropriate amendment.	AMEND 0002