

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

General Settings

Property	Value
Common Settings	
System Normal Message	CFCC Schwartz Center
Terminal Operation	Local Terminal
LED Blink	1
Time Format	USA
Local Control	Full Control
IP Accessibility	Disabled
Alarm Scrolling	Enabled
AC Delay	Enabled
Regional Setting	US
Timers	
Enable Auto Silence	Disabled
Auto Silence(mm:ss)	00:00
Silence Inhibit(mm:ss)	00:00
Alarm Verification(mm:ss)	00:00
NCM Thresholds	
NCM Thresholds	PortA:High, PortB:High
Network Style	
Network Style	Style 4
Relay Configuration	
Security Relay	Security
Supervisory Relay	Supervisory
Utilities	
DCC Participation	Disabled
Enable Power Supply Charger	Enabled
ACS Terminal Mode	7 Bits
Battery Size	>26Ahr
Printer Baud Rate	9600
Misc Settings	
Drill Mode	Standard
Mass Notification System	
Mass Notification Priority	Fire is a higher priority than Mass Notification
Waterflow Settings	
Silenceable Waterflow	NO
Sounderbase Power Monitor Settings	
Sounder Base Standby Power Monitoring	Disabled
PHOTO/CO Device Setting	

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Property	Value
Photo Supervisory Latching	Disabled
CO Supervisory Latching	Disabled
NFPA Trouble Reminder	
Trouble Reminder Options	0
Trouble Reminder Duration	24 Hours
Wireless Settings	
Wireless Weak Link Trouble Reporting	Enabled
ACCLIMATE Device Settings	
Acclimate Photo Supervisory Latching	Disabled
Special Function - ZF0	
Pre-Signal Delay Time(mm:ss)	03:00
Enable Positive Alarm Sequence	Disabled
Function#5	
F#5-Enable	Disabled
F#5 - Time Control Functions	
F#5-On(hh:mm)	08:00
F#5-Off(hh:mm)	17:00
F#5-Sunday	Disabled
F#5-Monday	Disabled
F#5-Tuesday	Disabled
F#5-Wednesday	Disabled
F#5-Thursday	Disabled
F#5-Friday	Disabled
F#5-Saturday	Disabled
F#5-Holiday	Disabled
Function#6	
F#6-Enable	Disabled
F#6 - Time Control Functions	
F#6-On(hh:mm)	08:00
F#6-Off(hh:mm)	23:00
F#6-Sunday	Disabled
F#6-Monday	Disabled
F#6-Tuesday	Disabled
F#6-Wednesday	Disabled
F#6-Thursday	Disabled
F#6-Friday	Disabled
F#6-Saturday	Disabled
F#6-Holiday	Disabled
F#8 - Bell Code	

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Property	Value
Bell Code	SYSTEM SENSOR STROBE
Function#9	
PreAlarm	Alert

ACS Address Maps

ACS Settings

Terminal Mode	ACS	UDACT
Disabled	Disabled	NO

ACS Mapping

ACS Board	Configured Map
1	M
2	*
3	*
4	*
5	*
6	*
7	*
8	*
9	*
10	*
11	*
12	*
13	*
14	*
15	*
16	*
17	*
18	*
19	*
20	*
21	*
22	*
23	*
24	*
25	*
26	*
27	*
28	*
29	*
30	*

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

ACS Board	Configured Map
31	*
32	*

Programmable ACS Groups

User Map	ACS Point	Function	Source	Source Label	Source Extended Label
1	11	Monitor / Control	Z32	Zone 32	
1	40	Monitor / Control	Z0	General Alarm	

Network Mapping

Node	Resound	WalkTest	MassNotification
1	Enabled	Enabled	Disabled
2	Enabled	Enabled	Disabled
3	Enabled	Enabled	Disabled
4	Enabled	Enabled	Disabled
5	Enabled	Enabled	Disabled
6	Enabled	Enabled	Disabled
7	Enabled	Enabled	Disabled
8	Enabled	Enabled	Disabled
9	Enabled	Enabled	Disabled
10	Enabled	Enabled	Disabled
11	Enabled	Enabled	Disabled
12	Enabled	Enabled	Disabled
13	Enabled	Enabled	Disabled
14	Enabled	Enabled	Disabled
15	Enabled	Enabled	Disabled
16	Enabled	Enabled	Disabled
17	Enabled	Enabled	Disabled
18	Enabled	Enabled	Disabled
19	Enabled	Enabled	Disabled
20	Enabled	Enabled	Disabled
21	Enabled	Enabled	Disabled
22	Enabled	Enabled	Disabled
23	Enabled	Enabled	Disabled
24	Enabled	Enabled	Disabled
25	Enabled	Enabled	Disabled
26	Enabled	Enabled	Disabled
27	Enabled	Enabled	Disabled

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
28	Enabled	Enabled	Disabled
29	Enabled	Enabled	Disabled
30	Enabled	Enabled	Disabled
31	Enabled	Enabled	Disabled
32	Enabled	Enabled	Disabled
33	Enabled	Enabled	Disabled
34	Enabled	Enabled	Disabled
35	Enabled	Enabled	Disabled
36	Enabled	Enabled	Disabled
37	Enabled	Enabled	Disabled
38	Enabled	Enabled	Disabled
39	Enabled	Enabled	Disabled
40	Enabled	Enabled	Disabled
41	Enabled	Enabled	Disabled
42	Enabled	Enabled	Disabled
43	Enabled	Enabled	Disabled
44	Enabled	Enabled	Disabled
45	Enabled	Enabled	Disabled
46	Enabled	Enabled	Disabled
47	Enabled	Enabled	Disabled
48	Enabled	Enabled	Disabled
49	Enabled	Enabled	Disabled
50	Enabled	Enabled	Disabled
51	Enabled	Enabled	Disabled
52	Enabled	Enabled	Disabled
53	Enabled	Enabled	Disabled
54	Enabled	Enabled	Disabled
55	Enabled	Enabled	Disabled
56	Enabled	Enabled	Disabled
57	Enabled	Enabled	Disabled
58	Enabled	Enabled	Disabled
59	Enabled	Enabled	Disabled
60	Enabled	Enabled	Disabled
61	Enabled	Enabled	Disabled
62	Enabled	Enabled	Disabled
63	Enabled	Enabled	Disabled
64	Enabled	Enabled	Disabled
65	Enabled	Enabled	Disabled
66	Enabled	Enabled	Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
67	Enabled	Enabled	Disabled
68	Enabled	Enabled	Disabled
69	Enabled	Enabled	Disabled
70	Enabled	Enabled	Disabled
71	Enabled	Enabled	Disabled
72	Enabled	Enabled	Disabled
73	Enabled	Enabled	Disabled
74	Enabled	Enabled	Disabled
75	Enabled	Enabled	Disabled
76	Enabled	Enabled	Disabled
77	Enabled	Enabled	Disabled
78	Enabled	Enabled	Disabled
79	Enabled	Enabled	Disabled
80	Enabled	Enabled	Disabled
81	Enabled	Enabled	Disabled
82	Enabled	Enabled	Disabled
83	Enabled	Enabled	Disabled
84	Enabled	Enabled	Disabled
85	Enabled	Enabled	Disabled
86	Enabled	Enabled	Disabled
87	Enabled	Enabled	Disabled
88	Enabled	Enabled	Disabled
89	Enabled	Enabled	Disabled
90	Enabled	Enabled	Disabled
91	Enabled	Enabled	Disabled
92	Enabled	Enabled	Disabled
93	Enabled	Enabled	Disabled
94	Enabled	Enabled	Disabled
95	Enabled	Enabled	Disabled
96	Enabled	Enabled	Disabled
97	Enabled	Enabled	Disabled
98	Enabled	Enabled	Disabled
99	Enabled	Enabled	Disabled
100	Enabled	Enabled	Disabled
101	Enabled	Enabled	Disabled
102	Enabled	Enabled	Disabled
103	Enabled	Enabled	Disabled
104	Enabled	Enabled	Disabled
105	Enabled	Enabled	Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
106	Enabled	Enabled	Disabled
107	Enabled	Enabled	Disabled
108	Enabled	Enabled	Disabled
109	Enabled	Enabled	Disabled
110	Enabled	Enabled	Disabled
111	Enabled	Enabled	Disabled
112	Enabled	Enabled	Disabled
113	Enabled	Enabled	Disabled
114	Enabled	Enabled	Disabled
115	Enabled	Enabled	Disabled
116	Enabled	Enabled	Disabled
117	Enabled	Enabled	Disabled
118	Enabled	Enabled	Disabled
119	Enabled	Enabled	Disabled
120	Enabled	Enabled	Disabled
121	Enabled	Enabled	Disabled
122	Enabled	Enabled	Disabled
123	Enabled	Enabled	Disabled
124	Enabled	Enabled	Disabled
125	Enabled	Enabled	Disabled
126	Enabled	Enabled	Disabled
127	Enabled	Enabled	Disabled
128	Enabled	Enabled	Disabled
129	Enabled	Enabled	Disabled
130	Enabled	Enabled	Disabled
131	Enabled	Enabled	Disabled
132	Enabled	Enabled	Disabled
133	Enabled	Enabled	Disabled
134	Enabled	Enabled	Disabled
135	Enabled	Enabled	Disabled
136	Enabled	Enabled	Disabled
137	Enabled	Enabled	Disabled
138	Enabled	Enabled	Disabled
139	Enabled	Enabled	Disabled
140	Enabled	Enabled	Disabled
141	Enabled	Enabled	Disabled
142	Enabled	Enabled	Disabled
143	Enabled	Enabled	Disabled
144	Enabled	Enabled	Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
145	Enabled	Enabled	Disabled
146	Enabled	Enabled	Disabled
147	Enabled	Enabled	Disabled
148	Enabled	Enabled	Disabled
149	Enabled	Enabled	Disabled
150	Enabled	Enabled	Disabled
151	Enabled	Enabled	Disabled
152	Enabled	Enabled	Disabled
153	Enabled	Enabled	Disabled
154	Enabled	Enabled	Disabled
155	Enabled	Enabled	Disabled
156	Enabled	Enabled	Disabled
157	Enabled	Enabled	Disabled
158	Enabled	Enabled	Disabled
159	Enabled	Enabled	Disabled
160	Enabled	Enabled	Disabled
161	Enabled	Enabled	Disabled
162	Enabled	Enabled	Disabled
163	Enabled	Enabled	Disabled
164	Enabled	Enabled	Disabled
165	Enabled	Enabled	Disabled
166	Enabled	Enabled	Disabled
167	Enabled	Enabled	Disabled
168	Enabled	Enabled	Disabled
169	Enabled	Enabled	Disabled
170	Enabled	Enabled	Disabled
171	Enabled	Enabled	Disabled
172	Enabled	Enabled	Disabled
173	Enabled	Enabled	Disabled
174	Enabled	Enabled	Disabled
175	Enabled	Enabled	Disabled
176	Enabled	Enabled	Disabled
177	Enabled	Enabled	Disabled
178	Enabled	Enabled	Disabled
179	Enabled	Enabled	Disabled
180	Enabled	Enabled	Disabled
181	Enabled	Enabled	Disabled
182	Enabled	Enabled	Disabled
183	Enabled	Enabled	Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
184	Enabled	Enabled	Disabled
185	Enabled	Enabled	Disabled
186	Enabled	Enabled	Disabled
187	Enabled	Enabled	Disabled
188	Enabled	Enabled	Disabled
189	Enabled	Enabled	Disabled
190	Enabled	Enabled	Disabled
191	Enabled	Enabled	Disabled
192	Enabled	Enabled	Disabled
193	Enabled	Enabled	Disabled
194	Enabled	Enabled	Disabled
195	Enabled	Enabled	Disabled
196	Enabled	Enabled	Disabled
197	Enabled	Enabled	Disabled
198	Enabled	Enabled	Disabled
199	Enabled	Enabled	Disabled
200	Enabled	Enabled	Disabled
201	Enabled	Enabled	Disabled
202	Enabled	Enabled	Disabled
203	Enabled	Enabled	Disabled
204	Enabled	Enabled	Disabled
205	Enabled	Enabled	Disabled
206	Enabled	Enabled	Disabled
207	Enabled	Enabled	Disabled
208	Enabled	Enabled	Disabled
209	Enabled	Enabled	Disabled
210	Enabled	Enabled	Disabled
211	Enabled	Enabled	Disabled
212	Enabled	Enabled	Disabled
213	Enabled	Enabled	Disabled
214	Enabled	Enabled	Disabled
215	Enabled	Enabled	Disabled
216	Enabled	Enabled	Disabled
217	Enabled	Enabled	Disabled
218	Enabled	Enabled	Disabled
219	Enabled	Enabled	Disabled
220	Enabled	Enabled	Disabled
221	Enabled	Enabled	Disabled
222	Enabled	Enabled	Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Node	Resound	WalkTest	MassNotification
223	Enabled	Enabled	Disabled
224	Enabled	Enabled	Disabled
225	Enabled	Enabled	Disabled
226	Enabled	Enabled	Disabled
227	Enabled	Enabled	Disabled
228	Enabled	Enabled	Disabled
229	Enabled	Enabled	Disabled
230	Enabled	Enabled	Disabled
231	Enabled	Enabled	Disabled
232	Enabled	Enabled	Disabled
233	Enabled	Enabled	Disabled
234	Enabled	Enabled	Disabled
235	Enabled	Enabled	Disabled
236	Enabled	Enabled	Disabled
237	Enabled	Enabled	Disabled
238	Enabled	Enabled	Disabled
239	Enabled	Enabled	Disabled
240	Enabled	Enabled	Disabled

Loops

Loop ID	Installed	Wiring Style	Detector Mode	Module Mode
1	Enabled	Style 6	FlashScan	FlashScan
2	Enabled	Style 6	CLIP	CLIP

All Detectors

All Detectors : Part 1

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
1	1	Smoke(Photo)	PHOTO	Corridor 100B		8	8	N/A	Z3	Z32				N/A
1	2	Smoke(Photo)	PHOTO	Corridor 100B		8	8	N/A	Z3	Z32				N/A
1	3	Smoke(Photo)	PHOTO	Corridor by Rm 106		8	8	N/A	Z3	Z32				N/A
1	4	Smoke(Photo)	PHOTO	Corridor by Rm 108		8	8	N/A	Z3	Z32				N/A

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
1	5	Smoke(Photo)	PHOTO	Mens Locker Room		8	8	N/A	Z3	Z32				N/A
1	6	Smoke(Photo)	PHOTO	Corridor by Rm 109		8	8	N/A	Z3	Z32				N/A
1	7	Smoke(Photo)	PHOTO	Womens Locker Room		8	8	N/A	Z3	Z32				N/A
1	8	Smoke(Beam)	PHOTO	Corridor by Rm 116		N/A	8	N/A	Z3	Z32				N/A
1	9	Smoke(Photo)	PHOTO	Athletic Storage		8	8	N/A	Z3	Z32				N/A
1	10	Smoke(Photo)	PHOTO	Athletic Storage		8	8	N/A	Z3	Z32				N/A
1	11	Smoke(Photo)	PHOTO	Corridor by Womens L		8	8	N/A	Z3	Z32				N/A
1	12	Smoke(Photo)	PHOTO	Womens Locker Room		8	8	N/A	Z3	Z32				N/A
1	13	Smoke(Photo)	PHOTO	Team Instruction Rm		8	8	N/A	Z3	Z32				N/A
1	14	Smoke(Photo)	PHOTO	Team Instruction Rm		8	8	N/A	Z3	Z32				N/A
1	15	Smoke(Photo)	PHOTO	Corridor by Laundry		8	8	N/A	Z3	Z32				N/A
1	16	Smoke(Photo)	PHOTO	Trainers Room		8	8	N/A	Z3	Z32				N/A
1	17	Smoke(Photo)	PHOTO	Weight Room		8	8	N/A	Z3	Z32				N/A
1	18	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
1	19	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
1	20	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
2	1	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3	Z32				N/A
2	2	Smoke(Photo)	PHOTO	Lobby 100		8	8	N/A	Z3	Z32				N/A
2	3	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3	Z32				N/A
2	4	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3					N/A
2	5	Smoke(Photo)	PHOTO	electric 117		8	8	N/A	Z3					N/A
2	6	Smoke(Photo)	PHOTO	corridor 121		8	8	N/A	Z3					N/A
2	7	Smoke(Photo)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	8	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	9	Smoke(Photo)	PHOTO	Storage 108		8	8	N/A	Z3					N/A

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
2	10	Smoke(Photo)	PHOTO	corridor 124		8	8	N/A	Z3					N/A
2	11	Smoke(Photo)	PHOTO	office 110		8	8	N/A	Z3					N/A
2	12	Smoke(Photo)	PHOTO	Corridor 111		8	8	N/A	Z3					N/A
2	13	Smoke(Photo)	PHOTO	Janitor Closet		8	8	N/A	Z3					N/A
2	14	Smoke(Photo)	PHOTO	Com Room 112		8	8	N/A	Z3					N/A
2	16	Smoke(Photo)	PHOTO	Consession 101		8	8	N/A	Z3					N/A
2	18	Smoke(Photo)	PHOTO	Serv 102		8	8	N/A	Z3					N/A
2	19	Smoke(Duct P)	PHOTO	mech room		8	8	N/A	Z3					N/A
2	20	Smoke(Photo)	PHOTO	Mech room		8	8	N/A	Z3					N/A
2	21	Smoke(Duct P)	PHOTO	Mech room		8	8	N/A	Z3					N/A
2	22	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	23	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	24	Smoke(Duct P)	PHOTO	office 1100		8	8	N/A	Z3					N/A
2	30	Smoke(Beam)	BEAM	GYM		N/A	5	N/A	Z3					N/A
2	31	Smoke(Beam)	BEAM	Gym		N/A	5	N/A	Z3					N/A

All Detectors : Part 2

LOOP	Device ADDR	Alarm. Ver. Part.	Cooperative Detector Mode	INT SND	Tone1	Tone1 Control	Tone2	Tone2 Control	Tone3	Tone3 Control	VOL	REF DETR	FLOW FLT THLD	FLOW FLT DELAY
1	1	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	2	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	3	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	4	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	5	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Alarm. Ver. Part.	Cooperative Detector Mode	INT SND	Tone1	Tone1 Control	Tone2	Tone2 Control	Tone3	Tone3 Control	VOL	REF DETR	FLOW FLT THLD	FLOW FLT DELAY
1	6	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	7	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	8	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	9	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	10	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	11	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	12	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	13	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	14	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	15	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	16	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	17	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	18	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	19	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	20	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	1	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	2	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	3	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	4	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	5	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	6	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	7	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	8	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	9	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	10	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	11	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	12	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	13	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	14	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	16	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	18	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	19	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	20	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	21	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	22	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	23	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Alarm. Ver. Part.	Cooperative Detector Mode	INT SND	Tone1	Tone1 Control	Tone2	Tone2 Control	Tone3	Tone3 Control	VOL	REF DETR	FLOW FLT THLD	FLOW FLT DELAY
2	24	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	30	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	31	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

All Modules

LOOP	Device ADDR	Module Type	Type Code Label	FlashScan Type	Custom Label	Extended Label	Walk Test Part.	SW INH	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	Waterflow Delay
1	1	Monitor	Monitor	MANUAL STATION	Corridor by Locker R		N/A	N/A	N/A	Z4	Z32				N/A
1	2	Control	Relay	RELAY	Doas #1		Enabled	Disabled	Yes w/ Resound Fire	Z0					N/A
1	3	Control	Relay	RELAY	Doas #2		Enabled	Disabled	Yes w/ Resound Fire	Z0					N/A
1	4	Control	Relay	RELAY	PGAC #1		Enabled	Disabled	Yes w/ Resound Fire	Z0					N/A
1	5	Monitor	Monitor	MANUAL STATION	Southeast Exit		N/A	N/A	N/A	Z4	Z32				N/A
1	86	Control	Relay	RELAY	MODULE ADDR 1M086		Enabled	Disabled	Yes w/ Resound Fire	Z0					N/A
1	87	Monitor	Monitor	MINI/DUAL MONITOR	MODULE ADDR 1M087		N/A	N/A	N/A	Z8					N/A
1	88	Control	Relay	RELAY	MODULE ADDR 1M088		Enabled	Disabled	Yes w/ Resound Fire	Z0					N/A
1	89	Monitor	Monitor	MINI/DUAL MONITOR	MODULE ADDR 1M089		N/A	N/A	N/A	Z8					N/A
2	1	Monitor	Pull Station	MANUAL STATION	GYM		N/A	N/A	N/A	Z4					N/A
2	2	Monitor	Pull Station	MANUAL STATION	Gym corridor 122		N/A	N/A	N/A	Z4					N/A

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Module Type	Type Code Label	FlashScan Type	Custom Label	Extended Label	Walk Test Part.	SW INH	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	Waterflow Delay
2	3	Monitor	Pull Station	MANUAL STATION	Corridor 121		N/A	N/A	N/A	Z4					N/A
2	4	Control	Relay	RELAY	ahu shutdown mezzani		Disabled	Disabled	No	Z0					N/A
2	5	Monitor	Pull Station	MANUAL STATION	Corridor 111		N/A	N/A	N/A	Z4					N/A
2	6	Monitor	Pull Station	MANUAL STATION	Gym corridor 123		N/A	N/A	N/A	Z4					N/A
2	9	Monitor	Pull Station	MANUAL STATION	Gym		N/A	N/A	N/A	Z4					N/A
2	11	Monitor	Pull Station	MANUAL STATION	Corridor 104		N/A	N/A	N/A	Z4					N/A
2	12	Monitor	Tamper	MONITOR	mech rm		N/A	N/A	N/A	Z4					N/A
2	13	Monitor	Waterflow	MONITOR	mech rm		N/A	N/A	N/A	Z4					0

All Detectors & All Modules All Detectors & Modules : Part 1

All Detectors

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
1	1	Smoke(Photo)	PHOTO	Corridor 100B		8	8	N/A	Z3	Z32				N/A
1	2	Smoke(Photo)	PHOTO	Corridor 100B		8	8	N/A	Z3	Z32				N/A
1	3	Smoke(Photo)	PHOTO	Corridor by Rm 106		8	8	N/A	Z3	Z32				N/A
1	4	Smoke(Photo)	PHOTO	Corridor by Rm 108		8	8	N/A	Z3	Z32				N/A
1	5	Smoke(Photo)	PHOTO	Mens Locker Room		8	8	N/A	Z3	Z32				N/A
1	6	Smoke(Photo)	PHOTO	Corridor by Rm 109		8	8	N/A	Z3	Z32				N/A
1	7	Smoke(Photo)	PHOTO	Womens Locker Room		8	8	N/A	Z3	Z32				N/A
1	8	Smoke(Beam)	PHOTO	Corridor by Rm 116		N/A	8	N/A	Z3	Z32				N/A
1	9	Smoke(Photo)	PHOTO	Athletic Storage		8	8	N/A	Z3	Z32				N/A

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
1	10	Smoke(Photo)	PHOTO	Athletic Storage		8	8	N/A	Z3	Z32				N/A
1	11	Smoke(Photo)	PHOTO	Corridor by Womens L		8	8	N/A	Z3	Z32				N/A
1	12	Smoke(Photo)	PHOTO	Womens Locker Room		8	8	N/A	Z3	Z32				N/A
1	13	Smoke(Photo)	PHOTO	Team Instruction Rm		8	8	N/A	Z3	Z32				N/A
1	14	Smoke(Photo)	PHOTO	Team Instruction Rm		8	8	N/A	Z3	Z32				N/A
1	15	Smoke(Photo)	PHOTO	Corridor by Laundry		8	8	N/A	Z3	Z32				N/A
1	16	Smoke(Photo)	PHOTO	Trainers Room		8	8	N/A	Z3	Z32				N/A
1	17	Smoke(Photo)	PHOTO	Weight Room		8	8	N/A	Z3	Z32				N/A
1	18	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
1	19	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
1	20	Smoke(Photo)	PHOTO	Under North Bleacher		8	8	N/A	Z3	Z32				N/A
2	1	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3	Z32				N/A
2	2	Smoke(Photo)	PHOTO	Lobby 100		8	8	N/A	Z3	Z32				N/A
2	3	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3	Z32				N/A
2	4	Smoke(Photo)	PHOTO	lobby 100		8	8	N/A	Z3					N/A
2	5	Smoke(Photo)	PHOTO	electric 117		8	8	N/A	Z3					N/A
2	6	Smoke(Photo)	PHOTO	corridor 121		8	8	N/A	Z3					N/A
2	7	Smoke(Photo)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	8	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	9	Smoke(Photo)	PHOTO	Storage 108		8	8	N/A	Z3					N/A
2	10	Smoke(Photo)	PHOTO	corridor 124		8	8	N/A	Z3					N/A
2	11	Smoke(Photo)	PHOTO	office 110		8	8	N/A	Z3					N/A
2	12	Smoke(Photo)	PHOTO	Corridor 111		8	8	N/A	Z3					N/A
2	13	Smoke(Photo)	PHOTO	Janitor Closet		8	8	N/A	Z3					N/A

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Type Code Label	FlashScan Type	Custom Label	Extended Label	Pre-Alarm	Fire Alarm	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5	CBE 6
2	14	Smoke(Photo)	PHOTO	Com Room 112		8	8	N/A	Z3					N/A
2	16	Smoke(Photo)	PHOTO	Consession 101		8	8	N/A	Z3					N/A
2	18	Smoke(Photo)	PHOTO	Serv 102		8	8	N/A	Z3					N/A
2	19	Smoke(Duct P)	PHOTO	mech room		8	8	N/A	Z3					N/A
2	20	Smoke(Photo)	PHOTO	Mech room		8	8	N/A	Z3					N/A
2	21	Smoke(Duct P)	PHOTO	Mech room		8	8	N/A	Z3					N/A
2	22	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	23	Smoke(Duct P)	PHOTO	mezzanine		8	8	N/A	Z3					N/A
2	24	Smoke(Duct P)	PHOTO	office 1100		8	8	N/A	Z3					N/A
2	30	Smoke(Beam)	BEAM	GYM		N/A	5	N/A	Z3					N/A
2	31	Smoke(Beam)	BEAM	Gym		N/A	5	N/A	Z3					N/A

All Modules

LOOP	Device ADDR	Module Type	Type Code Label	FlashScan Type	Custom Label	Extended Label	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5
1	1	Monitor	Monitor	MANUAL STATION	Corridor by Locker R		N/A	Z4	Z32			
1	2	Control	Relay	RELAY	Doas #1		Yes w/ Resound Fire	Z0				
1	3	Control	Relay	RELAY	Doas #2		Yes w/ Resound Fire	Z0				
1	4	Control	Relay	RELAY	PGAC #1		Yes w/ Resound Fire	Z0				
1	5	Monitor	Monitor	MANUAL STATION	Southeast Exit		N/A	Z4	Z32			
1	86	Control	Relay	RELAY	MODULE ADDR 1M086		Yes w/ Resound Fire	Z0				
1	87	Monitor	Monitor	MINI/DUAL MONITOR	MODULE ADDR 1M087		N/A	Z8				
1	88	Control	Relay	RELAY	MODULE ADDR 1M088		Yes w/ Resound Fire	Z0				

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Module Type	Type Code Label	FlashScan Type	Custom Label	Extended Label	Silenceable	CBE 1	CBE 2	CBE 3	CBE 4	CBE 5
1	89	Monitor	Monitor	MINI/DUAL MONITOR	MODULE ADDR 1M089		N/A	Z8				
2	1	Monitor	Pull Station	MANUAL STATION	GYM		N/A	Z4				
2	2	Monitor	Pull Station	MANUAL STATION	Gym corridor 122		N/A	Z4				
2	3	Monitor	Pull Station	MANUAL STATION	Corridor 121		N/A	Z4				
2	4	Control	Relay	RELAY	ahu shutdown mezzani		No	Z0				
2	5	Monitor	Pull Station	MANUAL STATION	Corridor 111		N/A	Z4				
2	6	Monitor	Pull Station	MANUAL STATION	Gym corridor 123		N/A	Z4				
2	9	Monitor	Pull Station	MANUAL STATION	Gym		N/A	Z4				
2	11	Monitor	Pull Station	MANUAL STATION	Corridor 104		N/A	Z4				
2	12	Monitor	Tamper	MONITOR	mech rm		N/A	Z4				
2	13	Monitor	Waterflow	MONITOR	mech rm		N/A	Z4				

All Detectors & Modules : Part 2

All Detectors

LOOP	Device ADDR	Alarm. Ver. Part.	Cooperative Detector Mode	INT SND	Tone1	Tone1 Control	Tone2	Tone2 Control	Tone3	Tone3 Control	VOL	REF DETR	FLOW FLT THLD	FLOW FLT DELAY
1	1	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	2	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	3	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	4	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	5	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	6	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	7	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	8	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	9	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	10	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	11	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Alarm. Ver. Part.	Cooperative Detector Mode	INT SND	Tone1	Tone1 Control	Tone2	Tone2 Control	Tone3	Tone3 Control	VOL	REF DETR	FLOW FLT THLD	FLOW FLT DELAY
1	12	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	13	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	14	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	15	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	16	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	17	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	18	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	19	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
1	20	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	1	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	2	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	3	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	4	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	5	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	6	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	7	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	8	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	9	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	10	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	11	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	12	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	13	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	14	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	16	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	18	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	19	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	20	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	21	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	22	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	23	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	24	Disabled	None(N)	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	30	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
2	31	Disabled	N/A	Disabled	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

All Modules

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

LOOP	Device ADDR	Walk Test Part.	SW INH	Waterflow Delay
1	1	N/A	N/A	N/A
1	2	Enabled	Disabled	N/A
1	3	Enabled	Disabled	N/A
1	4	Enabled	Disabled	N/A
1	5	N/A	N/A	N/A
1	86	Enabled	Disabled	N/A
1	87	N/A	N/A	N/A
1	88	Enabled	Disabled	N/A
1	89	N/A	N/A	N/A
2	1	N/A	N/A	N/A
2	2	N/A	N/A	N/A
2	3	N/A	N/A	N/A
2	4	Disabled	Disabled	N/A
2	5	N/A	N/A	N/A
2	6	N/A	N/A	N/A
2	9	N/A	N/A	N/A
2	11	N/A	N/A	N/A
2	12	N/A	N/A	N/A
2	13	N/A	N/A	0

Holiday List

General Zones

Local	Label	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Silenceable
0	General Alarm											Disabled
1	Zone 01											Disabled
2	Zone 02											Disabled
3	Zone 03											Disabled
4	Zone 04											Disabled
5	Zone 05											Disabled
6	Zone 06											Disabled
7	Zone 07											Disabled
8	Zone 08											Disabled
9	Zone 09											Disabled
10	Zone 10											Disabled

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Local	Label	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Silenceable
11	Zone 11											Disabled
12	Zone 12											Disabled
13	Zone 13											Disabled
14	Zone 14											Disabled
15	Zone 15											Disabled
16	Zone 16											Disabled
17	Zone 17											Disabled
18	Zone 18											Disabled
19	Zone 19											Disabled
20	Zone 20											Disabled
21	Zone 21											Disabled
22	Zone 22											Disabled
23	Zone 23											Disabled
24	Zone 24											Disabled
25	Zone 25											Disabled
26	Zone 26											Disabled
27	Zone 27											Disabled
28	Zone 28											Disabled
29	Zone 29											Disabled
30	Zone 30											Disabled
31	Zone 31											Disabled
32	Zone 32											Disabled
33	Zone 33											Disabled
34	Zone 34											Disabled
35	Zone 35											Disabled
36	Zone 36											Disabled
37	Zone 37											Disabled
38	Zone 38											Disabled
39	Zone 39											Disabled
40	Zone 40											Disabled
41	Zone 41											Disabled
42	Zone 42											Disabled
43	Zone 43											Disabled
44	Zone 44											Disabled
45	Zone 45											Disabled
46	Zone 46											Disabled
47	Zone 47											Disabled
48	Zone 48											Disabled
49	Zone 49											Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Local	Label	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Silenceable
50	Zone 50											Disabled
51	Zone 51											Disabled
52	Zone 52											Disabled
53	Zone 53											Disabled
54	Zone 54											Disabled
55	Zone 55											Disabled
56	Zone 56											Disabled
57	Zone 57											Disabled
58	Zone 58											Disabled
59	Zone 59											Disabled
60	Zone 60											Disabled
61	Zone 61											Disabled
62	Zone 62											Disabled
63	Zone 63											Disabled
64	Zone 64											Disabled
65	Zone 65											Disabled
66	Zone 66											Disabled
67	Zone 67											Disabled
68	Zone 68											Disabled
69	Zone 69											Disabled
70	Zone 70											Disabled
71	Zone 71											Disabled
72	Zone 72											Disabled
73	Zone 73											Disabled
74	Zone 74											Disabled
75	Zone 75											Disabled
76	Zone 76											Disabled
77	Zone 77											Disabled
78	Zone 78											Disabled
79	Zone 79											Disabled
80	Zone 80											Disabled
81	Zone 81											Disabled
82	Zone 82											Disabled
83	Zone 83											Disabled
84	Zone 84											Disabled
85	Zone 85											Disabled
86	Zone 86											Disabled
87	Zone 87											Disabled
88	Zone 88											Disabled

Notifier, Inc.
<http://www.notifier.com>

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Local	Label	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Node#	Zone#	Silenceable
89	Zone 89											Disabled
90	Zone 90											Disabled
91	Zone 91											Disabled
92	Zone 92											Disabled
93	Zone 93											Disabled
94	Zone 94											Disabled
95	Zone 95											Disabled
96	Zone 96											Disabled
97	Zone 97											Disabled
98	Zone 98											Disabled
99	Zone 99											Disabled

Releasing Zones

Zone Address	Delay Time (mm:ss)	Abort Switch	Cross Zoning	Soak Time (hh:mm:ss)
0	0:0	ULI	No	0:0:0
1	0:0	ULI	No	0:0:0
2	0:0	ULI	No	0:0:0
3	0:0	ULI	No	0:0:0
4	0:0	ULI	No	0:0:0
5	0:0	ULI	No	0:0:0
6	0:0	ULI	No	0:0:0
7	0:0	ULI	No	0:0:0
8	0:0	ULI	No	0:0:0
9	0:0	ULI	No	0:0:0

Bell Circuits

ID	Type Code Label	Custom Label	Extended Label	Walk Test Part.	SW INH	Silenceable	CBE1	CBE2	CBE3	CBE4	CBE5
1	Control	PANEL CIRCUIT NO. 1		Enabled	Disabled	Yes w/ Resound Fire	Z0				
2	Control	PANEL CIRCUIT NO. 2		Enabled	Disabled	Yes w/ Resound Fire	Z0				
3	Control	PANEL CIRCUIT NO. 3		Enabled	Disabled	Yes w/ Resound Fire	Z0				
4	Control	PANEL CIRCUIT NO. 4		Enabled	Disabled	Yes w/ Resound Fire	Z0				

Complete Panel Report

NFS2-640

Panel DB Version:26.0

Project Details: (Name : CFCC Schwartz Center , Version : 1.0)

Node Address: 0

Notifier VeriFire Tools 10.00 build 68

Friday, May 17, 2019 9:43:54 AM

Logic Equations