

1 SECTION 235216 - CONDENSING BOILERS

2 PART 1 - GENERAL

3 1.1 SUMMARY

4 A. Section Includes:

- 5 1. Floor-mounted, fire-tube condensing boilers.  
6 2. Condensate-neutralization units.

7 1.2 ACTION SUBMITTALS

8 A. Product Data: For each type of product.

9 B. Shop Drawings: For boilers, boiler trim, and accessories.

- 10 1. Include plans, elevations, sections, and mounting details.  
11 2. Include details of equipment assemblies. Indicate dimensions, weights, loads, required  
12 clearances, method of field assembly, components, and location and size of each field  
13 connection.  
14 3. Include diagrams for power, signal, and control wiring.

15 1.3 INFORMATIONAL SUBMITTALS

16 A. Field quality-control reports.

17 B. Sample warranty.

18 1.4 CLOSEOUT SUBMITTALS

19 A. Operation and maintenance data.

20 1.5 WARRANTY

21 A. Manufacturer's Warranty: Manufacturer agrees to repair or replace components of boilers that fail  
22 in materials or workmanship within specified warranty period. Where "prorated" is indicated, the  
23 boiler manufacturer will cover the indicated percentage of cost of replacement parts. With  
24 "prorated" type, covered cost decreases as age of equipment increases.

25 1. Warranty Period for Floor-Mounted Fire-Tube Condensing Boilers:

- 26 a. Heat Exchanger and Tank: Free from defects in material and workmanship.  
27 b. Warranty Coverage: Prorated Year 0 to 5 - 100 percent; Year 6 to 7 - 50 percent;  
28 Year 8 to 9 - 30 percent; Year 10 - 10 percent for years from date of Substantial  
29 Completion.

1 PART 2 - PRODUCTS

2 2.1 PERFORMANCE REQUIREMENTS

3 A. Electrical Components, Devices, and Accessories: Listed and labeled as defined in NFPA 70, by a  
4 qualified testing agency, and marked for intended location and application.

5 B. ASME Compliance: Fabricate and label boilers to comply with ASME Boiler and Pressure Vessel  
6 Code.

7 C. ASHRAE/IES 90.1 Compliance: Boilers shall have minimum efficiency in accordance with Table  
8 6.8.1-6 and other requirements in Ch. 6 of ASHRAE/IES 90.1.

9 D. ASHRAE 90.2 Compliance: Boilers shall have minimum efficiency in accordance with Ch. 6 of  
10 ASHRAE 90.2.

11 2.2 FLOOR-MOUNTED, FORCED-DRAFT, FIRE-TUBE CONDENSING BOILERS

12 A. Description: Factory-fabricated, -assembled, and -tested, fire-tube, forced-draft, condensing boiler  
13 with heat exchanger sealed pressure tight, built on a steel base, including insulated jacket; flue-  
14 gas vent; combustion-air intake connections; water supply, return, and condensate drain  
15 connections; and controls. Units are to be for water-heating service only.

16 B. Refer to schedule on design drawings for further information.

17 C. Burner: Dual fuel (gas and No. 2 fuel oil), forced draft.

18 2.3 CONTROLS

19 A. Refer to Section 230923 "Direct Digital Control (DDC) System for HVAC."

20 2.4 ELECTRICAL POWER

21 A. Controllers, Electrical Devices, and Wiring: Electrical devices and connections are shown on  
22 Drawings and specified in electrical Sections.

23 B. Single-Point Field Power Connection: Factory-installed and -wired switches, motor controllers,  
24 transformers, and other electrical devices necessary shall provide a single-point field power  
25 connection to boiler.

26 2.5 VENTING KITS

27 A. Kit: Complete system, ASTM A959, Type 29-4C stainless steel pipe, vent terminal, thimble, indoor  
28 plate, vent adapter, condensate trap and dilution tank, and sealant.

29 B. Combustion-Air Intake: Complete system, stainless steel pipe, vent terminal with screen, inlet air  
30 coupling, and sealant.

31 2.6 CONDENSATE-NEUTRALIZATION UNITS

32 A. Description: Factory-fabricated and -assembled condensate-neutralizing tank assembly of  
33 corrosion-resistant plastic material with threaded or flanged inlet and outlet pipe connections.  
34 Device functions to prevent acidic condensate from damaging grain system. It is to be piped to  
35 receive acidic condensate discharged from condensing boiler and neutralize it by chemical

1 reaction with replaceable neutralizing agent. Neutralized condensate is then piped to suitable  
2 drain.

### 3 2.7 SOURCE QUALITY CONTROL

4 A. UL Compliance, Oil-Fired: Test oil-fired boilers for compliance with UL 726. Boilers shall be listed  
5 and labeled by a testing agency acceptable to authorities having jurisdiction.

6 B. Burner and Hydrostatic Test: Factory adjust burner to eliminate excess oxygen, carbon dioxide,  
7 oxides of nitrogen emissions, and carbon monoxide in flue gas and to achieve combustion  
8 efficiency; perform hydrostatic test.

9 C. Test and inspect factory-assembled boilers, before shipping, in accordance with 2017 ASME Boiler  
10 and Pressure Vessel Code. Factory test boilers for safety and functionality; fill boiler with water,  
11 and fire throughout firing range, to prove operation of all safety components.

## 12 PART 3 - EXECUTION

### 13 3.1 BOILER INSTALLATION

14 A. Equipment Mounting:

15 1. Install floor-mounted boilers on cast-in-place concrete equipment base(s). Comply with  
16 requirements for equipment bases and foundations specified in Section 033000 "Cast-in-  
17 Place Concrete."

18 B. Assemble and install boiler trim.

19 C. Install electrical devices furnished with boiler but not specified to be factory mounted.

20 D. Install control wiring to field-mounted electrical devices.

### 21 3.2 PIPING CONNECTIONS

22 A. Comply with requirements for hydronic piping specified in Section 232113 "Hydronic Piping."

23 B. Connect piping to boilers, except safety relief valve connections, with flexible connectors of  
24 materials suitable for service. Flexible connectors and their installation are specified in  
25 Section 232116 "Hydronic Piping Specialties."

26 C. Drawings indicate general arrangement of piping, fittings, and specialties.

27 D. When installing piping adjacent to boiler, allow space for service and maintenance of condensing  
28 boilers. Arrange piping for easy removal of condensing boilers.

29 E. Install condensate drain piping to condensate-neutralization unit and from neutralization unit to  
30 nearest floor drain. Piping shall be at least full size of connection. Install piping with a minimum  
31 of 2 percent downward slope in direction of flow.

32 F. Install condensate piping from equipment drain connection to nearest floor drain. Piping shall be at  
33 least full size of connection. Install piping with a minimum of 2 percent downward slope in  
34 direction of flow.

1 G. Connect hot-water piping to supply- and return-boiler tapings with shutoff valve, and union or  
2 flange at each connection.

3 H. Install piping from safety relief valves to nearest floor drain.

### 4 3.3 DUCT CONNECTIONS

#### 5 A. Boiler Venting:

6 1. Install flue-venting kit and combustion-air intake.

7 2. Field fabricate and install boiler vent and combustion-air intake.

8 3. Utilize vent and intake duct material, size, and configuration as indicated in boiler  
9 manufacturer's instructions and to comply with UL 1738.

10 4. Connect boiler vent full size to boiler connections.

11 5. Comply with requirements in Section 235123 "Gas Vents."

12 6. Comply with all boiler manufacturer's installation instructions.

### 13 3.4 ELECTRICAL CONNECTIONS

14 A. Connect wiring in accordance with Section 260519 "Low-Voltage Electrical Power Conductors and  
15 Cables."

16 B. Ground equipment according to Section 260526 "Grounding and Bonding for Electrical Systems."

17 C. Install electrical devices furnished by manufacturer, but not factory mounted, according to NFPA 70  
18 and NECA 1.

19 D. Install nameplate for each electrical connection, indicating electrical equipment designation and  
20 circuit number feeding connection.

21 1. Nameplate shall be laminated acrylic or melamine plastic signs, as specified in  
22 Section 260553 "Identification for Electrical Systems."

### 23 3.5 CONTROL CONNECTIONS

24 A. Install control and electrical power wiring to field-mounted control devices.

25 B. Connect control wiring in accordance with Section 260523 "Control-Voltage Electrical Power  
26 Cables."

27 C. Install nameplate for each control connection, indicating field control panel designation and I/O  
28 control designation feeding connection.

29 1. Nameplate shall be laminated acrylic or melamine plastic signs, as specified in  
30 Section 260553 "Identification for Electrical Systems."

1 3.6 FIELD QUALITY CONTROL

2 A. Testing Agency, Owner: Owner will engage a qualified testing agency to perform tests and  
3 inspections.

4 B. Testing Agency, Contractor: Engage a qualified testing agency to perform tests and inspections.

5 C. Perform tests and inspections with the assistance of a factory-authorized service representative:

6 D. Tests and Inspections:

7 1. Perform installation and startup checks in accordance with manufacturer's written  
8 instructions.

9 2. Leak Test: Hydrostatic test. Repair leaks and retest until no leaks exist.

10 3. Operational Test: Start units to confirm proper motor rotation and unit operation. Adjust  
11 air-fuel ratio and combustion.

12 4. Test and adjust controls and safeties. Replace damaged and malfunctioning controls and  
13 equipment.

14 a. Check and adjust initial operating set points and high- and low-limit safety set  
15 points of fuel supply, water level, and water temperature.

16 b. Set field-adjustable switches and circuit-breaker trip ranges as indicated.

17 E. Boiler will be considered defective if it does not pass tests and inspections.

18 F. Prepare test and inspection reports.

19 G. Occupancy Adjustments: When requested within 12 months of date of Substantial Completion,  
20 provide on-site assistance in adjusting system to suit actual occupied conditions. Provide up to  
21 two visits to Project during other-than-normal occupancy hours for this purpose.

22 3.7 DEMONSTRATION

23 A. Engage a factory-authorized service representative to train Owner's maintenance personnel to  
24 adjust, operate, and maintain boilers. Refer to Section 017900 "Demonstration and Training."

25 1. Instructor shall be factory trained and certified.

26 2. Provide not less than two hours of training.

27 3. Train personnel in operation and maintenance and to obtain maximum efficiency in plant  
28 operation.

29 4. Provide instructional videos showing general operation and maintenance that are  
30 coordinated with operation and maintenance manuals.

31 5. Obtain Owner sign-off that training is complete.

32 6. Owner training shall be held at Project site.

33 END OF SECTION 235216