

April 24<sup>th</sup>, 2026

Contractors are hereby notified that this addendum shall become part of their Contract Documents. The following items are intended to revise and/or clarify the Contract Documents and shall be included in the contract. **All addenda and attachments are posted to the following website including the bid manual:**

<https://edificeinc.box.com/s/2bwk6utqmdk5sdpugocg0qxxlq5g7re>

**ITEMS INCLUDED WITHIN THIS ADDENDUM:**

1. Edifice Responses to Bidders Questions & Clarifications
2. Change to Scopes of Work

**EDIFICE RESPONSES TO BIDDER QUESTIONS:**

1. 05-001: Please reference Addendum 04. Bid RFI #34 response says to provide alternate pricing for foundation details 2&6/S303 and 6,9-11/S505 provide direction to provide bolted connections and isolation pads for alternate pricing; however, these alternates are not listed on the bid form. Please provide an updated bid form to include these alternates or confirm that these alternates are not to be priced/included.

*Response: No, there will be no additional alternate pricing for these details. Where alternate details are provided or "Contractor's Options" are shown, provide pricing that covers the most expensive option in your base bid, such that any of the details can be chosen during construction with no cost or schedule impact. Please disregard previous response to Addendum 04, Edifice Response #2 and follow this direction.*

2. 21-001: SOW 21-001, #37 states "Electrical trade package will include a single point connection to equipment. All electrical wiring, terminations, and raceways between equipment supplied herein, regardless of voltage, is the responsibility of THIS trade package." Please confirm this line item is to be removed from the fire protection scope, as it appears to be meant for the electrical subcontractor.

*Response: Main electrical power will still be provided by the electrician; however, where low voltage and communications connections are needed, but not shown on the drawings, this subcontractor is to provide the low voltage and communications connections. Please see revised SOW 21-001, #37 provided below.*

**CHANGE TO SCOPES OF WORK (SOW):**

**21-001, updated #37:** Electrical trade package will include a single point connection to equipment. All electrical wiring, terminations, and raceways between equipment supplied herein, ~~regardless of voltage~~ **for low voltage and communication wiring**, is the responsibility of THIS trade package."

**ATTACHMENTS:**

- None

End of Addendum 05